

**Choke Canyon / Lake Corpus Christi Reservoir System
Daily Status Report
Report Date: June 1, 2000**

RESERVOIR STATISTICS

	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined Reservoir System	
Date	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Volume (AcFt)	Percent of Capacity
FULL	220.5	695,271	100%	94.0	241,241	100%	936,512	100%
06/01/1999	204.5	350,518	50.4%	90.6	179,867	74.6%	530,385	56.6%
06/01/2000	199.6	271,062	39.0%	87.0	122,283	50.7%	393,345	42.0%
Weather Related Information								
	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined	
Date	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Evaporation (AcFt)	
05/31/2000	96	373	0.00	92	348	0.00	721	
MTD		8,411	3.31		8,754	1.22	17,165	

STREAM FLOWS

Gauging Station	05/31/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	105	5,751
NRTT: Nueces River at Tilden, Texas	2	44
FRTT: Frio River at Tilden, Texas	4	186
SMTT: San Miguel Creek at Tilden, Texas	0	1,094
ARWT: Atascosa River at Whitsett, Texas	22	4,184
Release from Choke Canyon Reservoir	66	2,031
NCAT: Nueces River at Calallen, Texas	353	2,422
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	44	5,118

ESTUARY INFLOWS and PASSTHRU REQUIREMENTS
(All values are in AcFt)

Target Passthru Monthly Target: 23,500 Salinity Relief Credit: 0 Effective:	23,500
Credit / -Deficit From Previous Month (Date Deficit Satisfied:)	38
Wastewater Return Flow Credit (Effective: 05/01/2000)	500
Required Passthru Target: 23,500 Reservoir Inflow: 5,118	5,118
Estuary Inflows (Measured at NCAT)	2,422
PassThru Surplus / -Deficit:	-2,158

Report Generated: 06/01/2000 at 8:37:03 AM

**Choke Canyon / Lake Corpus Christi Reservoir System
Daily Status Report
Report Date: June 2, 2000**

RESERVOIR STATISTICS

	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined Reservoir System	
Date	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Volume (AcFt)	Percent of Capacity
FULL	220.5	695,271	100%	94.0	241,241	100%	936,512	100%
06/02/1999	204.5	350,345	50.4%	90.6	178,666	74.1%	529,011	56.5%
06/02/2000	199.6	270,616	38.9%	87.0	121,410	50.3%	392,026	41.9%
Weather Related Information								
	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined	
Date	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Evaporation (AcFt)	
06/01/2000	96	346	0.00	92	347	0.00	693	693
MTD		346	0.00		347	0.00	693	693

STREAM FLOWS

Gauging Station	06/01/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	85	85
NRTT: Nueces River at Tilden, Texas	1	1
FRTT: Frio River at Tilden, Texas	1	1
SMTT: San Miguel Creek at Tilden, Texas	0	0
ARWT: Atascosa River at Whitsett, Texas	17	17
Release from Choke Canyon Reservoir	66	66
NCAT: Nueces River at Calallen, Texas	347	347
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	21	21

ESTUARY INFLOWS and PASSTHRU REQUIREMENTS

(All values are in AcFt)

Target Passthru Monthly Target: 23,000 Salinity Relief Credit: 0 Effective:	23,000
Credit / -Deficit From Previous Month (Date Deficit Satisfied:)	-2,158
Wastewater Return Flow Credit (Effective:)	0
Required Passthru Target: 23,000 Reservoir Inflow: 21	21
Estuary Inflows (Measured at NCAT)	347
PassThru Surplus / -Deficit:	-1,832

Report Generated: 06/02/2000 at 9:32:46 AM

**Choke Canyon / Lake Corpus Christi Reservoir System
Daily Status Report
Report Date: June 3, 2000**

RESERVOIR STATISTICS

	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined Reservoir System	
Date	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Volume (AcFt)	Percent of Capacity
FULL	220.5	695,271	100%	94.0	241,241	100%	936,512	100%
06/03/1999	204.5	349,825	50.3%	90.5	177,298	73.5%	527,123	56.3%
06/03/2000	199.5	270,022	38.8%	86.9	120,539	50.0%	390,561	41.7%
Weather Related Information								
	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined	
Date	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Evaporation (AcFt)	
06/02/2000	97	311	0.00	92	287	0.00	598	
MTD		657	0.00		634	0.00	1,291	

STREAM FLOWS

Gauging Station	06/02/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	79	165
NRTT: Nueces River at Tilden, Texas	0	1
FRTT: Frio River at Tilden, Texas	1	2
SMTT: San Miguel Creek at Tilden, Texas	0	0
ARWT: Atascosa River at Whitsett, Texas	12	29
Release from Choke Canyon Reservoir	66	131
NCAT: Nueces River at Calallen, Texas	363	711
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	15	35

ESTUARY INFLOWS and PASSTHRU REQUIREMENTS
(All values are in AcFt)

Target Passthru Monthly Target: 23,000 Salinity Relief Credit: 0 Effective:	23,000
Credit / -Deficit From Previous Month (Date Deficit Satisfied:)	-2,158
Wastewater Return Flow Credit (Effective:)	0
Required Passthru Target: 23,000 Reservoir Inflow: 35	35
Estuary Inflows (Measured at NCAT)	711
PassThru Surplus / -Deficit:	-1,483

**Choke Canyon / Lake Corpus Christi Reservoir System
Daily Status Report
Report Date: June 4, 2000**

RESERVOIR STATISTICS

	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined Reservoir System	
Date	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Volume (AcFt)	Percent of Capacity
FULL	220.5	695,271	100%	94.0	241,241	100%	936,512	100%
06/04/1999	204.5	349,134	50.2%	90.4	175,763	72.9%	524,897	56.0%
06/04/2000	199.5	269,578	38.8%	86.8	119,671	49.6%	389,249	41.6%
Weather Related Information								
	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined	
Date	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Evaporation (AcFt)	
06/03/2000	96	276	0.00	94	311	0.00	587	
MTD		933	0.00		945	0.00	1,878	

STREAM FLOWS

Gauging Station	06/03/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	73	238
NRTT: Nueces River at Tilden, Texas	0	1
FRTT: Frio River at Tilden, Texas	0	2
SMTT: San Miguel Creek at Tilden, Texas	0	0
ARWT: Atascosa River at Whitsett, Texas	10	39
Release from Choke Canyon Reservoir	66	197
NCAT: Nueces River at Calallen, Texas	429	1,139
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	8	44

ESTUARY INFLOWS and PASSTHRU REQUIREMENTS
(All values are in AcFt)

Target Passthru Monthly Target: 23,000 Salinity Relief Credit: 0 Effective:	23,000
Credit / -Deficit From Previous Month (Date Deficit Satisfied:)	-2,158
Wastewater Return Flow Credit (Effective:)	0
Required Passthru Target: 23,000 Reservoir Inflow: 44	44
Estuary Inflows (Measured at NCAT)	1,139
PassThru Surplus / -Deficit:	-1,062

**Choke Canyon / Lake Corpus Christi Reservoir System
Daily Status Report
Report Date: June 5, 2000**

RESERVOIR STATISTICS

	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined Reservoir System	
Date	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Volume (AcFt)	Percent of Capacity
FULL	220.5	695,271	100%	94.0	241,241	100%	936,512	100%
06/05/1999	204.4	348,961	50.2%	90.3	174,233	72.2%	523,194	55.9%
06/05/2000	199.7	273,150	39.3%	86.8	119,094	49.4%	392,244	41.9%
Weather Related Information								
	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined	
Date	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Evaporation (AcFt)	
06/04/2000	100	174	3.40	98	370	0.07	544	
MTD		1,107	3.40		1,315	0.07	2,422	

STREAM FLOWS

Gauging Station	06/04/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	75	314
NRTT: Nueces River at Tilden, Texas	2	4
FRTT: Frio River at Tilden, Texas	0	3
SMTT: San Miguel Creek at Tilden, Texas	0	0
ARWT: Atascosa River at Whitsett, Texas	9	48
Release from Choke Canyon Reservoir	66	262
NCAT: Nueces River at Calallen, Texas	421	1,560
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	10	54

ESTUARY INFLOWS and PASSTHRU REQUIREMENTS
(All values are in AcFt)

Target Passthru Monthly Target: 23,000 Salinity Relief Credit: 0 Effective:	23,000
Credit / -Deficit From Previous Month (Date Deficit Satisfied:)	-2,158
Wastewater Return Flow Credit (Effective:)	0
Required Passthru Target: 23,000 Reservoir Inflow: 54	54
Estuary Inflows (Measured at NCAT)	1,560
PassThru Surplus / -Deficit:	-652

Report Generated: 06/05/2000 at 8:46:31 AM

**Choke Canyon / Lake Corpus Christi Reservoir System
Daily Status Report
Report Date: June 6, 2000**

RESERVOIR STATISTICS

	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined Reservoir System	
Date	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Volume (AcFt)	Percent of Capacity
FULL	220.5	695,271	100%	94.0	241,241	100%	936,512	100%
06/06/1999	204.4	348,270	50.1%	90.3	173,725	72.0%	521,995	55.7%
06/06/2000	199.7	272,552	39.2%	86.8	118,805	49.2%	391,357	41.8%
Weather Related Information								
	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined	
Date	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Evaporation (AcFt)	
06/05/2000	83	87	0.00	83	109	0.00		196
MTD		1,194	3.40		1,424	0.07		2,618

STREAM FLOWS

Gauging Station	06/05/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	284	597
NRTT: Nueces River at Tilden, Texas	153	156
FRTT: Frio River at Tilden, Texas	26	28
SMTT: San Miguel Creek at Tilden, Texas	0	0
ARWT: Atascosa River at Whitsett, Texas	95	144
Release from Choke Canyon Reservoir	66	328
NCAT: Nueces River at Calallen, Texas	308	1,868
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	244	298

ESTUARY INFLOWS and PASSTHRU REQUIREMENTS
(All values are in AcFt)

Target Passthru Monthly Target: 23,000 Salinity Relief Credit: 0 Effective:	23,000
Credit / -Deficit From Previous Month (Date Deficit Satisfied:)	-2,158
Wastewater Return Flow Credit (Effective:)	0
Required Passthru Target: 23,000 Reservoir Inflow: 298	298
Estuary Inflows (Measured at NCAT)	1,868
PassThru Surplus / -Deficit:	-588

**Choke Canyon / Lake Corpus Christi Reservoir System
Daily Status Report
Report Date: June 7, 2000**

RESERVOIR STATISTICS

	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined Reservoir System	
Date	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Volume (AcFt)	Percent of Capacity
FULL	220.5	695,271	100%	94.0	241,241	100%	936,512	100%
06/07/1999	204.4	347,925	50.0%	90.2	173,386	71.9%	521,311	55.7%
06/07/2000	199.7	272,403	39.2%	86.8	118,517	49.1%	390,920	41.7%
Weather Related Information								
	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined	
Date	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Evaporation (AcFt)	
06/06/2000	90	287	0.00	91	277	0.00	564	
MTD		1,481	3.40		1,701	0.07	3,182	

STREAM FLOWS

Gauging Station	06/06/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	451	1,048
NRRT: Nueces River at Tilden, Texas	20	176
FRTT: Frio River at Tilden, Texas	40	68
SMTT: San Miguel Creek at Tilden, Texas	0	0
ARWT: Atascosa River at Whitsett, Texas	310	453
Release from Choke Canyon Reservoir	66	393
NCAT: Nueces River at Calallen, Texas	314	2,182
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	425	723

ESTUARY INFLOWS and PASSTHRU REQUIREMENTS
(All values are in AcFt)

Target Passthru Monthly Target: 23,000 Salinity Relief Credit: 0 Effective:	23,000
Credit / -Deficit From Previous Month (Date Deficit Satisfied: 06/06/2000)	-2,158
Wastewater Return Flow Credit (Effective: 06/07/2000)	500
Required Passthru Target: 23,000 Reservoir Inflow: 723	723
Estuary Inflows (Measured at NCAT)	2,182
PassThru Surplus / -Deficit:	-200

**Choke Canyon / Lake Corpus Christi Reservoir System
Daily Status Report
Report Date: June 8, 2000**

RESERVOIR STATISTICS

	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined Reservoir System	
Date	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Volume (AcFt)	Percent of Capacity
FULL	220.5	695,271	100%	94.0	241,241	100%	936,512	100%
06/08/1999	204.4	347,407	50.0%	90.2	172,540	71.5%	519,947	55.5%
06/08/2000	199.7	272,254	39.2%	86.8	119,238	49.4%	391,492	41.8%
Weather Related Information								
	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined	
Date	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Evaporation (AcFt)	
06/07/2000	90	252	0.00	91	269	0.00	521	
MTD		1,733	3.40		1,970	0.07	3,703	

STREAM FLOWS

Gauging Station	06/07/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	399	1,447
NRTT: Nueces River at Tilden, Texas	5	182
FRTT: Frio River at Tilden, Texas	24	92
SMTT: San Miguel Creek at Tilden, Texas	0	0
ARWT: Atascosa River at Whitsett, Texas	193	646
Release from Choke Canyon Reservoir	66	459
NCAT: Nueces River at Calallen, Texas	75	2,257
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	357	1,080

ESTUARY INFLOWS and PASSTHRU REQUIREMENTS
(All values are in AcFt)

Target Passthru Monthly Target: 23,000 Salinity Relief Credit: 0 Effective:	23,000
Credit / -Deficit From Previous Month (Date Deficit Satisfied: 06/06/2000)	-2,158
Wastewater Return Flow Credit (Effective: 06/07/2000)	500
Required Passthru Target: 23,000 Reservoir Inflow: 1,080	1,080
Estuary Inflows (Measured at NCAT)	2,257
PassThru Surplus / -Deficit:	-481

**Choke Canyon / Lake Corpus Christi Reservoir System
Daily Status Report
Report Date: June 9, 2000**

RESERVOIR STATISTICS

	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined Reservoir System	
Date	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Volume (AcFt)	Percent of Capacity
FULL	220.5	695,271	100%	94.0	241,241	100%	936,512	100%
06/09/1999	204.3	347,235	49.9%	90.2	172,202	71.4%	519,437	55.5%
06/09/2000	199.7	272,702	39.2%	86.8	118,661	49.2%	391,363	41.8%
Weather Related Information								
	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined	
Date	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Evaporation (AcFt)	
06/08/2000	90	244	0.57	100	302	0.00		546
MTD		1,977	3.97		2,272	0.07		4,249

STREAM FLOWS

Gauging Station	06/08/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	234	1,681
NRTT: Nueces River at Tilden, Texas	2	184
FRTT: Frio River at Tilden, Texas	9	101
SMTT: San Miguel Creek at Tilden, Texas	10	10
ARWT: Atascosa River at Whitsett, Texas	66	711
Release from Choke Canyon Reservoir	66	524
NCAT: Nueces River at Calallen, Texas	15	2,272
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	187	1,267

ESTUARY INFLOWS and PASSTHRU REQUIREMENTS
(All values are in AcFt)

Target Passthru Monthly Target: 23,000 Salinity Relief Credit: 0 Effective:	23,000
Credit / -Deficit From Previous Month (Date Deficit Satisfied: 06/06/2000)	-2,158
Wastewater Return Flow Credit (Effective: 06/07/2000)	500
Required Passthru Target: 23,000 Reservoir Inflow: 1,267	1,267
Estuary Inflows (Measured at NCAT)	2,272
PassThru Surplus / -Deficit:	-653

**Choke Canyon / Lake Corpus Christi Reservoir System
Daily Status Report
Report Date: June 10, 2000**

RESERVOIR STATISTICS

	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined Reservoir System	
Date	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Volume (AcFt)	Percent of Capacity
FULL	220.5	695,271	100%	94.0	241,241	100%	936,512	100%
06/10/1999	204.3	346,890	49.9%	90.1	171,526	71.1%	518,416	55.4%
06/10/2000	200.0	276,452	39.8%	86.8	119,094	49.4%	395,546	42.2%
Weather Related Information								
	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined	
Date	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Evaporation (AcFt)	
06/09/2000	88	88	2.64	89	101	0.46	189	
MTD		2,065	6.61		2,373	0.53	4,438	

STREAM FLOWS

Gauging Station	06/09/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	169	1,850
NRTT: Nueces River at Tilden, Texas	6	190
FRTT: Frio River at Tilden, Texas	15	116
SMTT: San Miguel Creek at Tilden, Texas	36	45
ARWT: Atascosa River at Whitsett, Texas	85	797
Release from Choke Canyon Reservoir	66	590
NCAT: Nueces River at Calallen, Texas	16	2,288
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	154	1,422

ESTUARY INFLOWS and PASSTHRU REQUIREMENTS
(All values are in AcFt)

Target Passthru Monthly Target: 23,000 Salinity Relief Credit: 0 Effective:	23,000
Credit / -Deficit From Previous Month (Date Deficit Satisfied: 06/06/2000)	-2,158
Wastewater Return Flow Credit (Effective: 06/07/2000)	500
Required Passthru Target: 23,000 Reservoir Inflow: 1,422	1,422
Estuary Inflows (Measured at NCAT)	2,288
PassThru Surplus / -Deficit:	-791

**Choke Canyon / Lake Corpus Christi Reservoir System
Daily Status Report
Report Date: June 11, 2000**

RESERVOIR STATISTICS

	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined Reservoir System	
Date	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Volume (AcFt)	Percent of Capacity
FULL	220.5	695,271	100%	94.0	241,241	100%	936,512	100%
06/11/1999	204.3	346,374	49.8%	90.1	170,852	70.8%	517,226	55.2%
06/11/2000	200.0	277,055	39.8%	86.9	120,394	49.9%	397,449	42.4%
Weather Related Information								
	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined	
Date	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Evaporation (AcFt)	
06/10/2000	85	132	0.40	87	169	0.05	301	
MTD		2,197	7.01		2,542	0.58	4,739	

STREAM FLOWS

Gauging Station	06/10/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	1,078	2,928
NRTT: Nueces River at Tilden, Texas	328	517
FRTT: Frio River at Tilden, Texas	83	199
SMTT: San Miguel Creek at Tilden, Texas	10	55
ARWT: Atascosa River at Whitsett, Texas	1,108	1,904
Release from Choke Canyon Reservoir	66	655
NCAT: Nueces River at Calallen, Texas	69	2,358
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	1,106	2,527

ESTUARY INFLOWS and PASSTHRU REQUIREMENTS
(All values are in AcFt)

Target Passthru Monthly Target: 23,000 Salinity Relief Credit: 0 Effective:	23,000
Credit / -Deficit From Previous Month (Date Deficit Satisfied: 06/06/2000)	-2,158
Wastewater Return Flow Credit (Effective: 06/07/2000)	500
Required Passthru Target: 23,000 Reservoir Inflow: 2,527	2,527
Estuary Inflows (Measured at NCAT)	2,358
PassThru Surplus / -Deficit:	-1,828

**Choke Canyon / Lake Corpus Christi Reservoir System
Daily Status Report
Report Date: June 12, 2000**

RESERVOIR STATISTICS

	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined Reservoir System	
Date	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Volume (AcFt)	Percent of Capacity
FULL	220.5	695,271	100%	94.0	241,241	100%	936,512	100%
06/12/1999	204.3	345,686	49.7%	90.1	170,347	70.6%	516,033	55.1%
06/12/2000	200.0	277,055	39.8%	87.0	122,137	50.6%	399,192	42.6%
Weather Related Information								
	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined	
Date	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Evaporation (AcFt)	
06/11/2000	91	299	0.00	91	297	0.00	596	
MTD		2,496	7.01		2,839	0.58	5,335	

STREAM FLOWS

Gauging Station	06/11/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	3,533	6,461
NRTT: Nueces River at Tilden, Texas	1,135	1,653
FRTT: Frio River at Tilden, Texas	97	297
SMTT: San Miguel Creek at Tilden, Texas	1	56
ARWT: Atascosa River at Whitsett, Texas	4,188	6,093
Release from Choke Canyon Reservoir	66	721
NCAT: Nueces River at Calallen, Texas	97	2,455
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	3,566	6,093

ESTUARY INFLOWS and PASSTHRU REQUIREMENTS
(All values are in AcFt)

Target Passthru Monthly Target: 23,000 Salinity Relief Credit: 0 Effective:	23,000
Credit / -Deficit From Previous Month (Date Deficit Satisfied: 06/06/2000)	-2,158
Wastewater Return Flow Credit (Effective: 06/07/2000)	500
Required Passthru Target: 23,000 Reservoir Inflow: 6,093	6,093
Estuary Inflows (Measured at NCAT)	2,455
PassThru Surplus / -Deficit:	-5,296

**Choke Canyon / Lake Corpus Christi Reservoir System
Daily Status Report
Report Date: June 13, 2000**

RESERVOIR STATISTICS

	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined Reservoir System	
Date	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Volume (AcFt)	Percent of Capacity
FULL	220.5	695,271	100%	94.0	241,241	100%	936,512	100%
06/13/1999	204.2	345,342	49.7%	90.0	169,674	70.3%	515,016	55.0%
06/13/2000	199.9	276,000	39.7%	87.3	126,542	52.5%	402,542	43.0%
Weather Related Information								
	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined	
Date	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Evaporation (AcFt)	
06/12/2000	91	246	0.32	92	302	0.00	548	
MTD		2,742	7.33		3,141	0.58	5,883	

STREAM FLOWS

Gauging Station	06/12/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	5,459	11,920
NRTT: Nueces River at Tilden, Texas	1,455	3,108
FRTT: Frio River at Tilden, Texas	48	344
SMTT: San Miguel Creek at Tilden, Texas	87	143
ARWT: Atascosa River at Whitsett, Texas	7,126	13,219
Release from Choke Canyon Reservoir	66	786
NCAT: Nueces River at Calallen, Texas	36	2,491
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	5,528	11,621

ESTUARY INFLOWS and PASSTHRU REQUIREMENTS
(All values are in AcFt)

Target Passthru Monthly Target: 23,000 Salinity Relief Credit: 0 Effective:	23,000
Credit / -Deficit From Previous Month (Date Deficit Satisfied: 06/06/2000)	-2,158
Wastewater Return Flow Credit (Effective: 06/07/2000)	500
Required Passthru Target: 23,000 Reservoir Inflow: 11,621	11,621
Estuary Inflows (Measured at NCAT)	2,491
PassThru Surplus / -Deficit:	-10,789

**Choke Canyon / Lake Corpus Christi Reservoir System
Daily Status Report
Report Date: June 14, 2000**

RESERVOIR STATISTICS

	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined Reservoir System	
Date	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Volume (AcFt)	Percent of Capacity
FULL	220.5	695,271	100%	94.0	241,241	100%	936,512	100%
06/14/1999	204.3	346,890	49.9%	90.0	169,338	70.2%	516,228	55.1%
06/14/2000	199.9	276,151	39.7%	87.6	131,313	54.4%	407,464	43.5%
Weather Related Information								
	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined	
Date	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Evaporation (AcFt)	
06/13/2000	92	281	0.00	93	341	0.00	622	
MTD		3,023	7.33		3,482	0.58	6,505	

STREAM FLOWS

Gauging Station	06/13/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	7,305	19,225
NRTT: Nueces River at Tilden, Texas	1,336	4,444
FRTT: Frio River at Tilden, Texas	28	372
SMTT: San Miguel Creek at Tilden, Texas	83	227
ARWT: Atascosa River at Whitsett, Texas	5,201	18,419
Release from Choke Canyon Reservoir	66	852
NCAT: Nueces River at Calallen, Texas	14	2,505
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	7,350	18,972

ESTUARY INFLOWS and PASSTHRU REQUIREMENTS
(All values are in AcFt)

Target Passthru Monthly Target: 23,000 Salinity Relief Credit: 0 Effective:	23,000
Credit / -Deficit From Previous Month (Date Deficit Satisfied: 06/06/2000)	-2,158
Wastewater Return Flow Credit (Effective: 06/07/2000)	500
Required Passthru Target: 23,000 Reservoir Inflow: 18,972	18,972
Estuary Inflows (Measured at NCAT)	2,505
PassThru Surplus / -Deficit:	-18,125

**Choke Canyon / Lake Corpus Christi Reservoir System
Daily Status Report
Report Date: June 15, 2000**

RESERVOIR STATISTICS

	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined Reservoir System	
Date	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Volume (AcFt)	Percent of Capacity
FULL	220.5	695,271	100%	94.0	241,241	100%	936,512	100%
06/15/1999	204.3	347,235	49.9%	90.0	169,003	70.1%	516,238	55.1%
06/15/2000	199.9	275,098	39.6%	88.0	137,078	56.8%	412,176	44.0%
Weather Related Information								
	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined	
Date	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Evaporation (AcFt)	
06/14/2000	91	184	0.00	91	321	0.00	505	
MTD		3,207	7.33		3,803	0.58	7,010	

STREAM FLOWS

Gauging Station	06/14/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	6,154	25,378
NRRT: Nueces River at Tilden, Texas	935	5,379
FRTT: Frio River at Tilden, Texas	12	383
SMTT: San Miguel Creek at Tilden, Texas	66	292
ARWT: Atascosa River at Whitsett, Texas	1,024	19,444
Release from Choke Canyon Reservoir	66	917
NCAT: Nueces River at Calallen, Texas	131	2,636
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	6,165	25,137

ESTUARY INFLOWS and PASSTHRU REQUIREMENTS
(All values are in AcFt)

Target Passthru Monthly Target: 23,000 Salinity Relief Credit: 0 Effective:	23,000
Credit / -Deficit From Previous Month (Date Deficit Satisfied: 06/06/2000)	-2,158
Wastewater Return Flow Credit (Effective: 06/07/2000)	500
Required Passthru Target: 23,000 Reservoir Inflow: 25,137	23,000
Estuary Inflows (Measured at NCAT)	2,636
PassThru Surplus / -Deficit:	-22,022

**Choke Canyon / Lake Corpus Christi Reservoir System
Daily Status Report
Report Date: June 16, 2000**

RESERVOIR STATISTICS

	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined Reservoir System	
Date	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Volume (AcFt)	Percent of Capacity
FULL	220.5	695,271	100%	94.0	241,241	100%	936,512	100%
06/16/1999	204.3	346,030	49.8%	90.0	170,010	70.5%	516,040	55.1%
06/16/2000	199.8	274,348	39.5%	88.1	138,458	57.4%	412,806	44.1%
Weather Related Information								
	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined	
Date	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Evaporation (AcFt)	
06/15/2000	92	253	0.00	96	349	0.00	602	
MTD		3,460	7.33		4,152	0.58	7,612	

STREAM FLOWS

Gauging Station	06/15/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	1,860	27,238
NRRT: Nueces River at Tilden, Texas	546	5,924
FRTT: Frio River at Tilden, Texas	153	536
SMTT: San Miguel Creek at Tilden, Texas	36	328
ARWT: Atascosa River at Whitsett, Texas	274	19,718
Release from Choke Canyon Reservoir	66	983
NCAT: Nueces River at Calallen, Texas	496	3,132
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	1,983	27,120

ESTUARY INFLOWS and PASSTHRU REQUIREMENTS
(All values are in AcFt)

Target Passthru Monthly Target: 23,000 Salinity Relief Credit: 0 Effective:	23,000
Credit / -Deficit From Previous Month (Date Deficit Satisfied: 06/06/2000)	-2,158
Wastewater Return Flow Credit (Effective: 06/07/2000)	500
Required Passthru Target: 23,000 Reservoir Inflow: 27,120	23,000
Estuary Inflows (Measured at NCAT)	3,132
PassThru Surplus / -Deficit:	-21,526

**Choke Canyon / Lake Corpus Christi Reservoir System
Daily Status Report
Report Date: June 17, 2000**

RESERVOIR STATISTICS

	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined Reservoir System	
Date	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Volume (AcFt)	Percent of Capacity
FULL	220.5	695,271	100%	94.0	241,241	100%	936,512	100%
06/17/1999	204.3	346,202	49.8%	90.0	169,506	70.3%	515,708	55.1%
06/17/2000	199.7	273,150	39.3%	88.1	137,997	57.2%	411,147	43.9%
Weather Related Information								
	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined	
Date	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Evaporation (AcFt)	
06/16/2000	92	279	0.00	96	349	0.02	628	
MTD		3,739	7.33		4,501	0.60	8,240	

STREAM FLOWS

Gauging Station	06/16/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	967	28,205
NRRT: Nueces River at Tilden, Texas	149	6,073
FRTT: Frio River at Tilden, Texas	204	741
SMTT: San Miguel Creek at Tilden, Texas	19	347
ARWT: Atascosa River at Whitsett, Texas	169	19,886
Release from Choke Canyon Reservoir	66	1,048
NCAT: Nueces River at Calallen, Texas	490	3,623
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	1,125	28,245

ESTUARY INFLOWS and PASSTHRU REQUIREMENTS
(All values are in AcFt)

Target Passthru Monthly Target: 23,000 Salinity Relief Credit: 0 Effective:	23,000
Credit / -Deficit From Previous Month (Date Deficit Satisfied: 06/06/2000)	-2,158
Wastewater Return Flow Credit (Effective: 06/07/2000)	500
Required Passthru Target: 23,000 Reservoir Inflow: 28,245	23,000
Estuary Inflows (Measured at NCAT)	3,623
PassThru Surplus / -Deficit:	-21,035

**Choke Canyon / Lake Corpus Christi Reservoir System
Daily Status Report
Report Date: June 18, 2000**

RESERVOIR STATISTICS

	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined Reservoir System	
Date	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Volume (AcFt)	Percent of Capacity
FULL	220.5	695,271	100%	94.0	241,241	100%	936,512	100%
06/18/1999	204.3	346,030	49.8%	90.0	169,171	70.1%	515,201	55.0%
06/18/2000	199.7	272,254	39.2%	88.0	137,690	57.1%	409,944	43.8%
Weather Related Information								
	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined	
Date	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Evaporation (AcFt)	
06/17/2000	93	295	0.00	96	375	0.27	670	
MTD		4,034	7.33		4,876	0.87	8,910	

STREAM FLOWS

Gauging Station	06/17/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	484	28,689
NRTT: Nueces River at Tilden, Texas	56	6,129
FRTT: Frio River at Tilden, Texas	75	816
SMTT: San Miguel Creek at Tilden, Texas	10	357
ARWT: Atascosa River at Whitsett, Texas	121	20,007
Release from Choke Canyon Reservoir	66	1,114
NCAT: Nueces River at Calallen, Texas	639	4,262
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	504	28,749

ESTUARY INFLOWS and PASSTHRU REQUIREMENTS
(All values are in AcFt)

Target Passthru Monthly Target: 23,000 Salinity Relief Credit: 0 Effective:	23,000
Credit / -Deficit From Previous Month (Date Deficit Satisfied: 06/06/2000)	-2,158
Wastewater Return Flow Credit (Effective: 06/07/2000)	500
Required Passthru Target: 23,000 Reservoir Inflow: 28,749	23,000
Estuary Inflows (Measured at NCAT)	4,262
PassThru Surplus / -Deficit:	-20,396

**Choke Canyon / Lake Corpus Christi Reservoir System
Daily Status Report
Report Date: June 19, 2000**

RESERVOIR STATISTICS

	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined Reservoir System	
Date	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Volume (AcFt)	Percent of Capacity
FULL	220.5	695,271	100%	94.0	241,241	100%	936,512	100%
06/19/1999	204.3	345,858	49.7%	90.0	170,010	70.5%	515,868	55.1%
06/19/2000	199.8	274,048	39.4%	88.1	137,997	57.2%	412,045	44.0%
Weather Related Information								
	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined	
Date	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Evaporation (AcFt)	
06/18/2000	95	332	0.90	92	277	0.56	609	
MTD		4,366	8.23		5,153	1.43	9,519	

STREAM FLOWS

Gauging Station	06/18/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	312	29,001
NRTT: Nueces River at Tilden, Texas	24	6,153
FRTT: Frio River at Tilden, Texas	44	860
SMTT: San Miguel Creek at Tilden, Texas	10	368
ARWT: Atascosa River at Whitsett, Texas	99	20,107
Release from Choke Canyon Reservoir	66	1,179
NCAT: Nueces River at Calallen, Texas	736	4,998
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	300	29,049

ESTUARY INFLOWS and PASSTHRU REQUIREMENTS
(All values are in AcFt)

Target Passthru Monthly Target: 23,000 Salinity Relief Credit: 0 Effective:	23,000
Credit / -Deficit From Previous Month (Date Deficit Satisfied: 06/06/2000)	-2,158
Wastewater Return Flow Credit (Effective: 06/07/2000)	500
Required Passthru Target: 23,000 Reservoir Inflow: 29,049	23,000
Estuary Inflows (Measured at NCAT)	4,998
PassThru Surplus / -Deficit:	-19,660

**Choke Canyon / Lake Corpus Christi Reservoir System
Daily Status Report
Report Date: June 20, 2000**

RESERVOIR STATISTICS

	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined Reservoir System	
Date	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Volume (AcFt)	Percent of Capacity
FULL	220.5	695,271	100%	94.0	241,241	100%	936,512	100%
06/20/1999	204.3	346,030	49.8%	90.1	170,852	70.8%	516,882	55.2%
06/20/2000	199.8	273,449	39.3%	88.0	137,231	56.9%	410,680	43.9%
Weather Related Information								
	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined	
Date	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Evaporation (AcFt)	
06/19/2000	91	279	0.00	93	339	0.00	618	
MTD		4,645	8.23		5,492	1.43	10,137	

STREAM FLOWS

Gauging Station	06/19/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	256	29,257
NRTT: Nueces River at Tilden, Texas	13	6,166
FRTT: Frio River at Tilden, Texas	30	890
SMTT: San Miguel Creek at Tilden, Texas	3	370
ARWT: Atascosa River at Whitsett, Texas	119	20,226
Release from Choke Canyon Reservoir	66	1,245
NCAT: Nueces River at Calallen, Texas	810	5,808
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	223	29,272

ESTUARY INFLOWS and PASSTHRU REQUIREMENTS
(All values are in AcFt)

Target Passthru Monthly Target: 23,000 Salinity Relief Credit: 0 Effective:	23,000
Credit / -Deficit From Previous Month (Date Deficit Satisfied: 06/06/2000)	-2,158
Wastewater Return Flow Credit (Effective: 06/07/2000)	500
Required Passthru Target: 23,000 Reservoir Inflow: 29,272	23,000
Estuary Inflows (Measured at NCAT)	5,808
PassThru Surplus / -Deficit:	-18,850

**Choke Canyon / Lake Corpus Christi Reservoir System
Daily Status Report
Report Date: June 21, 2000**

RESERVOIR STATISTICS

	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined Reservoir System	
Date	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Volume (AcFt)	Percent of Capacity
FULL	220.5	695,271	100%	94.0	241,241	100%	936,512	100%
06/21/1999	204.3	346,202	49.8%	90.4	175,083	72.6%	521,285	55.7%
06/21/2000	200.0	277,659	39.9%	87.9	135,398	56.1%	413,057	44.1%
Weather Related Information								
	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined	
Date	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Evaporation (AcFt)	
06/20/2000	93	264	0.00	96	364	0.00	628	
MTD		4,909	8.23		5,856	1.43	10,765	

STREAM FLOWS

Gauging Station	06/20/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	230	29,487
NRTT: Nueces River at Tilden, Texas	8	6,173
FRTT: Frio River at Tilden, Texas	19	908
SMTT: San Miguel Creek at Tilden, Texas	0	370
ARWT: Atascosa River at Whitsett, Texas	75	20,301
Release from Choke Canyon Reservoir	66	1,310
NCAT: Nueces River at Calallen, Texas	812	6,620
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	184	29,456

ESTUARY INFLOWS and PASSTHRU REQUIREMENTS
(All values are in AcFt)

Target Passthru Monthly Target: 23,000 Salinity Relief Credit: 0 Effective:	23,000
Credit / -Deficit From Previous Month (Date Deficit Satisfied: 06/06/2000)	-2,158
Wastewater Return Flow Credit (Effective: 06/07/2000)	500
Required Passthru Target: 23,000 Reservoir Inflow: 29,456	23,000
Estuary Inflows (Measured at NCAT)	6,620
PassThru Surplus / -Deficit:	-18,038

**Choke Canyon / Lake Corpus Christi Reservoir System
Daily Status Report
Report Date: June 22, 2000**

RESERVOIR STATISTICS

	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined Reservoir System	
Date	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Volume (AcFt)	Percent of Capacity
FULL	220.5	695,271	100%	94.0	241,241	100%	936,512	100%
06/22/1999	204.3	346,890	49.9%	90.4	176,786	73.3%	523,676	55.9%
06/22/2000	200.0	277,206	39.9%	87.9	134,941	55.9%	412,147	44.0%
Weather Related Information								
	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined	
Date	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Evaporation (AcFt)	
06/21/2000	93	308	0.00	95	345	0.00	653	
MTD		5,217	8.23		6,201	1.43	11,418	

STREAM FLOWS

Gauging Station	06/21/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	189	29,676
NRRT: Nueces River at Tilden, Texas	5	6,178
FRTT: Frio River at Tilden, Texas	12	920
SMTT: San Miguel Creek at Tilden, Texas	0	370
ARWT: Atascosa River at Whitsett, Texas	66	20,367
Release from Choke Canyon Reservoir	66	1,376
NCAT: Nueces River at Calallen, Texas	750	7,370
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	135	29,591

ESTUARY INFLOWS and PASSTHRU REQUIREMENTS
(All values are in AcFt)

Target Passthru Monthly Target: 23,000 Salinity Relief Credit: 0 Effective:	23,000
Credit / -Deficit From Previous Month (Date Deficit Satisfied: 06/06/2000)	-2,158
Wastewater Return Flow Credit (Effective: 06/07/2000)	500
Required Passthru Target: 23,000 Reservoir Inflow: 29,591	23,000
Estuary Inflows (Measured at NCAT)	7,370
PassThru Surplus / -Deficit:	-17,288

**Choke Canyon / Lake Corpus Christi Reservoir System
Daily Status Report
Report Date: June 23, 2000**

RESERVOIR STATISTICS

	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined Reservoir System	
Date	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Volume (AcFt)	Percent of Capacity
FULL	220.5	695,271	100%	94.0	241,241	100%	936,512	100%
06/23/1999	204.3	347,063	49.9%	90.5	176,956	73.4%	524,019	56.0%
06/23/2000	200.0	277,055	39.8%	87.8	133,879	55.5%	410,934	43.9%
Weather Related Information								
	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined	
Date	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Evaporation (AcFt)	
06/22/2000	93	290	0.00	94	318	0.00	608	
MTD		5,507	8.23		6,519	1.43	12,026	

STREAM FLOWS

Gauging Station	06/22/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	171	29,846
NRRT: Nueces River at Tilden, Texas	3	6,182
FRTT: Frio River at Tilden, Texas	8	928
SMTT: San Miguel Creek at Tilden, Texas	0	370
ARWT: Atascosa River at Whitsett, Texas	52	20,418
Release from Choke Canyon Reservoir	66	1,441
NCAT: Nueces River at Calallen, Texas	764	8,135
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	113	29,704

ESTUARY INFLOWS and PASSTHRU REQUIREMENTS
(All values are in AcFt)

Target Passthru Monthly Target: 23,000 Salinity Relief Credit: 0 Effective:	23,000
Credit / -Deficit From Previous Month (Date Deficit Satisfied: 06/06/2000)	-2,158
Wastewater Return Flow Credit (Effective: 06/07/2000)	500
Required Passthru Target: 23,000 Reservoir Inflow: 29,704	23,000
Estuary Inflows (Measured at NCAT)	8,135
PassThru Surplus / -Deficit:	-16,523

**Choke Canyon / Lake Corpus Christi Reservoir System
Daily Status Report
Report Date: June 24, 2000**

RESERVOIR STATISTICS

	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined Reservoir System	
Date	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Volume (AcFt)	Percent of Capacity
FULL	220.5	695,271	100%	94.0	241,241	100%	936,512	100%
06/24/1999	204.3	346,718	49.9%	90.5	177,640	73.6%	524,358	56.0%
06/24/2000	200.0	276,904	39.8%	87.7	132,066	54.7%	408,970	43.7%
Weather Related Information								
	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined	
Date	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Evaporation (AcFt)	
06/23/2000	97	369	0.00	100	386	0.00	755	
MTD		5,876	8.23		6,905	1.43	12,781	

STREAM FLOWS

Gauging Station	06/23/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	153	29,999
NRRT: Nueces River at Tilden, Texas	2	6,184
FRTT: Frio River at Tilden, Texas	6	934
SMTT: San Miguel Creek at Tilden, Texas	0	370
ARWT: Atascosa River at Whitsett, Texas	42	20,460
Release from Choke Canyon Reservoir	66	1,507
NCAT: Nueces River at Calallen, Texas	778	8,913
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	93	29,797

ESTUARY INFLOWS and PASSTHRU REQUIREMENTS
(All values are in AcFt)

Target Passthru Monthly Target: 23,000 Salinity Relief Credit: 0 Effective:	23,000
Credit / -Deficit From Previous Month (Date Deficit Satisfied: 06/06/2000)	-2,158
Wastewater Return Flow Credit (Effective: 06/07/2000)	500
Required Passthru Target: 23,000 Reservoir Inflow: 29,797	23,000
Estuary Inflows (Measured at NCAT)	8,913
PassThru Surplus / -Deficit:	-15,745

**Choke Canyon / Lake Corpus Christi Reservoir System
Daily Status Report
Report Date: June 25, 2000**

RESERVOIR STATISTICS

	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined Reservoir System	
Date	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Volume (AcFt)	Percent of Capacity
FULL	220.5	695,271	100%	94.0	241,241	100%	936,512	100%
06/25/1999	204.3	346,890	49.9%	90.5	178,153	73.8%	525,043	56.1%
06/25/2000	200.0	276,603	39.8%	87.6	130,863	54.2%	407,466	43.5%
Weather Related Information								
	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined	
Date	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Evaporation (AcFt)	
06/24/2000	97	386	0.00	98	455	0.00		841
MTD		6,262	8.23		7,360	1.43		13,622

STREAM FLOWS

Gauging Station	06/24/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	137	30,136
NRTT: Nueces River at Tilden, Texas	3	6,187
FRTT: Frio River at Tilden, Texas	4	938
SMTT: San Miguel Creek at Tilden, Texas	0	370
ARWT: Atascosa River at Whitsett, Texas	36	20,496
Release from Choke Canyon Reservoir	66	1,572
NCAT: Nueces River at Calallen, Texas	798	9,711
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	76	29,873

ESTUARY INFLOWS and PASSTHRU REQUIREMENTS
(All values are in AcFt)

Target Passthru Monthly Target: 23,000 Salinity Relief Credit: 0 Effective:	23,000
Credit / -Deficit From Previous Month (Date Deficit Satisfied: 06/06/2000)	-2,158
Wastewater Return Flow Credit (Effective: 06/07/2000)	500
Required Passthru Target: 23,000 Reservoir Inflow: 29,873	23,000
Estuary Inflows (Measured at NCAT)	9,711
PassThru Surplus / -Deficit:	-14,947

Report Generated: 06/25/2000 at 8:24:30 AM

**Choke Canyon / Lake Corpus Christi Reservoir System
Daily Status Report
Report Date: June 26, 2000**

RESERVOIR STATISTICS

	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined Reservoir System	
Date	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Volume (AcFt)	Percent of Capacity
FULL	220.5	695,271	100%	94.0	241,241	100%	936,512	100%
06/26/1999	204.3	346,718	49.9%	90.6	178,838	74.1%	525,556	56.1%
06/26/2000	200.0	276,452	39.8%	87.5	129,814	53.8%	406,266	43.4%
Weather Related Information								
	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined	
Date	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Evaporation (AcFt)	
06/25/2000	95	334	0.00	97	357	0.00	691	
MTD		6,596	8.23		7,717	1.43	14,313	

STREAM FLOWS

Gauging Station	06/25/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	125	30,261
NRRT: Nueces River at Tilden, Texas	1	6,188
FRTT: Frio River at Tilden, Texas	3	941
SMTT: San Miguel Creek at Tilden, Texas	0	370
ARWT: Atascosa River at Whitsett, Texas	34	20,529
Release from Choke Canyon Reservoir	66	1,638
NCAT: Nueces River at Calallen, Texas	699	10,409
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	62	29,935

ESTUARY INFLOWS and PASSTHRU REQUIREMENTS
(All values are in AcFt)

Target Passthru Monthly Target: 23,000 Salinity Relief Credit: 0 Effective:	23,000
Credit / -Deficit From Previous Month (Date Deficit Satisfied: 06/06/2000)	-2,158
Wastewater Return Flow Credit (Effective: 06/07/2000)	500
Required Passthru Target: 23,000 Reservoir Inflow: 29,935	23,000
Estuary Inflows (Measured at NCAT)	10,409
PassThru Surplus / -Deficit:	-14,249

**Choke Canyon / Lake Corpus Christi Reservoir System
Daily Status Report
Report Date: June 27, 2000**

RESERVOIR STATISTICS

	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined Reservoir System	
Date	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Volume (AcFt)	Percent of Capacity
FULL	220.5	695,271	100%	94.0	241,241	100%	936,512	100%
06/27/1999	204.3	346,202	49.8%	90.6	179,009	74.2%	525,211	56.1%
06/27/2000	199.9	276,151	39.7%	87.5	128,918	53.4%	405,069	43.3%
Weather Related Information								
	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined	
Date	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Evaporation (AcFt)	
06/26/2000	96	333	0.00	97	347	0.00	680	
MTD		6,929	8.23		8,064	1.43	14,993	

STREAM FLOWS

Gauging Station	06/26/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	117	30,378
NRTT: Nueces River at Tilden, Texas	1	6,189
FRTT: Frio River at Tilden, Texas	2	943
SMTT: San Miguel Creek at Tilden, Texas	0	370
ARWT: Atascosa River at Whitsett, Texas	30	20,559
Release from Choke Canyon Reservoir	66	1,703
NCAT: Nueces River at Calallen, Texas	721	11,130
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	53	29,988

ESTUARY INFLOWS and PASSTHRU REQUIREMENTS
(All values are in AcFt)

Target Passthru Monthly Target: 23,000 Salinity Relief Credit: 0 Effective:	23,000
Credit / -Deficit From Previous Month (Date Deficit Satisfied: 06/06/2000)	-2,158
Wastewater Return Flow Credit (Effective: 06/07/2000)	500
Required Passthru Target: 23,000 Reservoir Inflow: 29,988	23,000
Estuary Inflows (Measured at NCAT)	11,130
PassThru Surplus / -Deficit:	-13,528

**Choke Canyon / Lake Corpus Christi Reservoir System
Daily Status Report
Report Date: June 28, 2000**

RESERVOIR STATISTICS

	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined Reservoir System	
Date	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Volume (AcFt)	Percent of Capacity
FULL	220.5	695,271	100%	94.0	241,241	100%	936,512	100%
06/28/1999	204.3	346,718	49.9%	90.6	180,039	74.6%	526,757	56.2%
06/28/2000	199.9	275,398	39.6%	87.4	127,579	52.9%	402,977	43.0%
Weather Related Information								
	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined	
Date	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Evaporation (AcFt)	
06/27/2000	95	350	0.00	96	372	0.00	722	
MTD		7,279	8.23		8,436	1.43	15,715	

STREAM FLOWS

Gauging Station	06/27/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	115	30,494
NRTT: Nueces River at Tilden, Texas	1	6,189
FRTT: Frio River at Tilden, Texas	1	944
SMTT: San Miguel Creek at Tilden, Texas	0	370
ARWT: Atascosa River at Whitsett, Texas	28	20,587
Release from Choke Canyon Reservoir	66	1,769
NCAT: Nueces River at Calallen, Texas	754	11,884
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	51	30,039

ESTUARY INFLOWS and PASSTHRU REQUIREMENTS
(All values are in AcFt)

Target Passthru Monthly Target: 23,000 Salinity Relief Credit: 0 Effective:	23,000
Credit / -Deficit From Previous Month (Date Deficit Satisfied: 06/06/2000)	-2,158
Wastewater Return Flow Credit (Effective: 06/07/2000)	500
Required Passthru Target: 23,000 Reservoir Inflow: 30,039	23,000
Estuary Inflows (Measured at NCAT)	11,884
PassThru Surplus / -Deficit:	-12,774

**Choke Canyon / Lake Corpus Christi Reservoir System
Daily Status Report
Report Date: June 29, 2000**

RESERVOIR STATISTICS

	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined Reservoir System	
Date	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Volume (AcFt)	Percent of Capacity
FULL	220.5	695,271	100%	94.0	241,241	100%	936,512	100%
06/29/1999	204.3	346,374	49.8%	90.7	181,415	75.2%	527,789	56.4%
06/29/2000	199.9	274,948	39.5%	87.3	126,098	52.3%	401,046	42.8%
Weather Related Information								
	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined	
Date	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Evaporation (AcFt)	
06/28/2000	97	324	0.00	98	370	0.00	694	
MTD		7,603	8.23		8,806	1.43	16,409	

STREAM FLOWS

Gauging Station	06/28/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	117	30,611
NRTT: Nueces River at Tilden, Texas	0	6,189
FRTT: Frio River at Tilden, Texas	1	945
SMTT: San Miguel Creek at Tilden, Texas	0	370
ARWT: Atascosa River at Whitsett, Texas	26	20,613
Release from Choke Canyon Reservoir	66	1,834
NCAT: Nueces River at Calallen, Texas	730	12,615
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	52	30,091

ESTUARY INFLOWS and PASSTHRU REQUIREMENTS
(All values are in AcFt)

Target Passthru Monthly Target: 23,000 Salinity Relief Credit: 0 Effective:	23,000
Credit / -Deficit From Previous Month (Date Deficit Satisfied: 06/06/2000)	-2,158
Wastewater Return Flow Credit (Effective: 06/07/2000)	500
Required Passthru Target: 23,000 Reservoir Inflow: 30,091	23,000
Estuary Inflows (Measured at NCAT)	12,615
PassThru Surplus / -Deficit:	-12,043

**Choke Canyon / Lake Corpus Christi Reservoir System
Daily Status Report
Report Date: June 30, 2000**

RESERVOIR STATISTICS

	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined Reservoir System	
Date	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Elevation (Ft)	Volume (AcFt)	Percent of Capacity	Volume (AcFt)	Percent of Capacity
FULL	220.5	695,271	100%	94.0	241,241	100%	936,512	100%
06/30/1999	204.3	346,890	49.9%	90.8	182,795	75.8%	529,685	56.6%
06/30/2000	199.8	274,497	39.5%	87.2	125,214	51.9%	399,711	42.7%
Weather Related Information								
	Choke Canyon Reservoir			Lake Corpus Christi Reservoir			Combined	
Date	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Air Temp (°F)	Evaporation (AcFt)	Rainfall (Inches)	Evaporation (AcFt)	
06/29/2000	97	332	0.00	97	343	0.00	675	
MTD		7,935	8.23		9,149	1.43	17,084	

STREAM FLOWS

Gauging Station	06/29/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	113	30,724
NRTT: Nueces River at Tilden, Texas	0	6,189
FRTT: Frio River at Tilden, Texas	1	945
SMTT: San Miguel Creek at Tilden, Texas	0	370
ARWT: Atascosa River at Whitsett, Texas	24	20,637
Release from Choke Canyon Reservoir	66	1,900
NCAT: Nueces River at Calallen, Texas	732	13,347
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	48	30,140

ESTUARY INFLOWS and PASSTHRU REQUIREMENTS
(All values are in AcFt)

Target Passthru Monthly Target: 23,000 Salinity Relief Credit: 0 Effective:	23,000
Credit / -Deficit From Previous Month (Date Deficit Satisfied: 06/06/2000)	-2,158
Wastewater Return Flow Credit (Effective: 06/07/2000)	500
Required Passthru Target: 23,000 Reservoir Inflow: 30,140	23,000
Estuary Inflows (Measured at NCAT)	13,347
PassThru Surplus / -Deficit:	-11,311