# Choke Canyon / Lake Corpus Christi Reservoir System Daily Status Report Report Date: July 1, 2000

## RESERVOIR STATISTICS

	Choke Canyon Reservoir					Lake Corpus Christi Reservoir						Combined Reservoir System		
Date	Elevation (Ft)	Volume (AcFt)	Perce Capa	-			Volu (Ac		Percent of Capacity			Percent of Capacity		
FULL	220.5	695,271		100%		94.0	94.0 241,241		100	% 936,5	12	100%		
07/01/1999	204.3	346,374	4	19.8%		90.6	0.6 180,210		74.7	% 526,5	84	56.2%		
07/01/2000	199.8	274,048	3	39.4%	87.1		123	3,745	51.3	% 397,793		42.5%		
			Wea	ather R	Relate	ed Info	orma	tion						
	Cho	ke Canyor	Reser	voir	Lake Corpus Christi Reservoir						Combined			
Date	Air Temp (°F)	Evapor (Acl		Rainfa (Inche		1			poration AcFt)	Rainfall (Inches)	E	vaporation (AcFt)		
06/30/2000	97		332	332 0.		98			376	0.00		708		
MTD			8,267	8	3.23				9,525	1.43		17,792		

## STREAM FLOWS

Gauging Station	06/30/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	109	30,833
NRTT: Nueces River at Tilden, Texas	0	6,189
FRTT: Frio River at Tilden, Texas	0	945
SMTT: San Miguel Creek at Tilden, Texas	0	370
ARWT: Atascosa River at Whitsett, Texas	24	20,660
Release from Choke Canyon Reservoir	66	1,965
NCAT: Nueces River at Calallen, Texas	715	14,062
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	44	30,184

## **ESTUARY INFLOWS and PASSTHRU REQUIREMENTS** (All values are in AcFt)

Target Passthru	
Monthly Target: 23,000	23,000
Salinity Relief Credit: 0 Effective:	
Credit / -Deficit From Previous Month (Date Deficit Satisfied: 06/06/2000)	-2,158
Wastewater Return Flow Credit (Effective: 06/07/2000)	500
Required Passthru	
Target: 23,000	23,000
Reservoir Inflow: 30,184	
Estuary Inflows (Measured at NCAT)	14,062
PassThru Surplus / -Deficit:	-10,596

Report Generated: 07/01/2000 at 8:39:58 AM

# Choke Canyon / Lake Corpus Christi Reservoir System Daily Status Report Report Date: July 2, 2000

## RESERVOIR STATISTICS

	Choke Canyon Reservoir					Lake Corpus Christi Reservoir					Combined Reservoir System		
Date	Elevation (Ft)	Volume (AcFt)		Percent of Capacity				ıme Ft)	Percent of Capacity	_		Percent of Capacity	
FULL	220.5	695,271		100%		94.0	241	1,241 10		% 936,5	512	100%	
07/02/1999	204.3	345,858	4	9.7%		90.6	6 179,695		74.5	% 525,5	553	56.1%	
07/02/2000	199.8	273,599	3	9.4%	87.0		122	2,429	50.7	% 396,0	)28	42.3%	
			Wea	ather I	Rela	ted Info	orma	tion					
	Cho	ke Canyor	Reser	voir	Lake Corpus Christi Reservoi					ervoir		Combined	
Date	Air Temp	Evapor (Acl							poration AcFt)	Rainfall (Inches)	E	vaporation (AcFt)	
07/01/2000	99		392	392 0		98			399	0.00		791	
MTD			392	(	0.00				399	0.00		791	

## STREAM FLOWS

Gauging Station	07/01/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	107	107
NRTT: Nueces River at Tilden, Texas	0	0
FRTT: Frio River at Tilden, Texas	0	0
SMTT: San Miguel Creek at Tilden, Texas	0	0
ARWT: Atascosa River at Whitsett, Texas	22	22
Release from Choke Canyon Reservoir	66	66
NCAT: Nueces River at Calallen, Texas	719	719
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	42	42

## **ESTUARY INFLOWS and PASSTHRU REQUIREMENTS** (All values are in AcFt)

Target Passthru  Monthly Target: 4,500 Salinity Relief Credit: 0 Effective:	4,500
Credit / -Deficit From Previous Month (Date Deficit Satisfied: )	-10,596
Wastewater Return Flow Credit (Effective: )	0
Required Passthru Target: 4,500 Reservoir Inflow: 42	42
Estuary Inflows (Measured at NCAT)	719
PassThru Surplus / -Deficit:	-9,919

Report Generated: 07/02/2000 at 5:34:37 PM

# Choke Canyon / Lake Corpus Christi Reservoir System Daily Status Report Report Date: July 3, 2000

## RESERVOIR STATISTICS

	Choke	r	Lake Cor	pus C	hristi		Combined Reservoir System				
Date	Elevation (Ft)	Volume (AcFt)	Perce Capa		Elevation (Ft)			Percent of Capacity	_		Percent of Capacity
FULL	220.5	695,271		100%	94.0	241	1,241	100	% 936,5	12	100%
07/03/1999	204.2	345,514	4	9.7%	90.5	177	7,640	73.6	% 523,1	54	55.9%
07/03/2000	199.7	273,150	3	9.3%	86.9	86.9 121,119		50.2	% 394,2	69	42.1%
			Wea	ather R	elated Inf	orma	tion				
	Cho	ke Canyor	Reser	voir	Lake Corpus Christi Reservoir Combine					Combined	
Date	Air Temp (°F)	Evapor (Acl		Rainfa (Inche		-		poration AcFt)	Rainfall (Inches)	E	vaporation (AcFt)
07/02/2000	97		392	0.	.00 97	'		423	0.00		815
MTD			784	0.	.00			822	0.00		1,606

## STREAM FLOWS

Gauging Station	07/02/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	105	212
NRTT: Nueces River at Tilden, Texas	0	0
FRTT: Frio River at Tilden, Texas	0	0
SMTT: San Miguel Creek at Tilden, Texas	0	0
ARWT: Atascosa River at Whitsett, Texas	20	42
Release from Choke Canyon Reservoir	66	131
NCAT: Nueces River at Calallen, Texas	732	1,451
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	40	82

## ESTUARY INFLOWS and PASSTHRU REQUIREMENTS

(All values are in AcFt)

Target Passthru	
Monthly Target: 4,500	4,500
Salinity Relief Credit: 0 Effective:	
Credit / -Deficit From Previous Month (Date Deficit Satisfied: )	-10,596
Wastewater Return Flow Credit (Effective: )	0
Required Passthru	
Target: 4,500	82
Reservoir Inflow: 82	
Estuary Inflows (Measured at NCAT)	1,451
PassThru Surplus / -Deficit:	-9,227

Report Generated: 07/03/2000 at 8:39:35 AM

# Choke Canyon / Lake Corpus Christi Reservoir System Daily Status Report Report Date: July 4, 2000

## RESERVOIR STATISTICS

	Choke Canyon Reservoir					Lake Corpus Christi Reservoir						Combined Reservoir System		
Date	Elevation (Ft)	Volume (AcFt)		Percent of Capacity				ume :Ft)	Percent of Capacity	-		Percent of Capacity		
FULL	220.5	695,271		100%		94.0	241	1,241	100	% 936,5	512	100%		
07/04/1999	204.2	345,514	4	9.7%		90.4	176,615		73.2	% 522,1	29	55.8%		
07/04/2000	199.7	272,254	3	9.2%	86.9		120	),394	49.9	% 392, <del>6</del>	548	41.9%		
			Wea	ather F	Relat	ed Inf	orma	tion						
	Cho	ke Canyor	Reser	voir	Lake Corpus Christi Reservoir					ervoir	Combined			
Date	Air Temp	Evapor (Ac		I .				l .	poration AcFt)	Rainfall (Inches)	E	vaporation (AcFt)		
07/03/2000	98		417	0	0.00	96			413	0.00		830		
MTD			1,201	0	0.00				1,235	0.00		2,436		

## STREAM FLOWS

Gauging Station	07/03/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	103	316
NRTT: Nueces River at Tilden, Texas	0	0
FRTT: Frio River at Tilden, Texas	0	0
SMTT: San Miguel Creek at Tilden, Texas	0	0
ARWT: Atascosa River at Whitsett, Texas	20	61
Release from Choke Canyon Reservoir	66	197
NCAT: Nueces River at Calallen, Texas	750	2,201
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	38	119

## ESTUARY INFLOWS and PASSTHRU REQUIREMENTS

(All values are in AcFt)

Target Passthru Monthly Target: 4,500 Salinity Relief Credit: 0 Effective:	4,500
Credit / -Deficit From Previous Month (Date Deficit Satisfied: )	-10,596
Wastewater Return Flow Credit (Effective: )	0
Required Passthru Target: 4,500 Reservoir Inflow: 119	119
Estuary Inflows (Measured at NCAT)	2,201
PassThru Surplus / -Deficit:	-8,514

Report Generated: 07/04/2000 at 8:37:43 AM

# Choke Canyon / Lake Corpus Christi Reservoir System Daily Status Report Report Date: July 5, 2000

## RESERVOIR STATISTICS

	Choke Canyon Reservoir					Lake Corpus Christi Reservoir						Combined Reservoir System		
Date	Elevation (Ft)	Volume (AcFt)		Percent of Capacity		ration Ft)	Volu (Ac		Percent of Capacity	-		Percent of Capacity		
FULL	220.5	695,271		100%		94.0	241	,241	100	% 936,	512	100%		
07/05/1999	204.3	346,890	4	9.9%		90.4	175	5,933	72.9	% 522,	323	55.8%		
07/05/2000	199.7	271,956	3	9.1%		86.8	119	9,238	49.4	% 391,	194	41.8%		
			Wea	ather F	Relat	ed Inf	orma	tion						
	Cho	ke Canyor	Reser	voir		Lal	ce Co	rpus (	Christi Res	ervoir		Combined		
Date	Air Temp (°F)	Evapor (Acl		Rainf (Inch		- 1			poration AcFt)	Rainfall (Inches)		vaporation (AcFt)		
07/04/2000	98		373	0	0.00	96			420	0.00		793		
MTD			1,574	0	0.00				1,655	0.00		3,229		

## STREAM FLOWS

Gauging Station	07/04/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	99	415
NRTT: Nueces River at Tilden, Texas	0	0
FRTT: Frio River at Tilden, Texas	0	1
SMTT: San Miguel Creek at Tilden, Texas	0	0
ARWT: Atascosa River at Whitsett, Texas	18	80
Release from Choke Canyon Reservoir	66	262
NCAT: Nueces River at Calallen, Texas	723	2,924
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	34	153

## ESTUARY INFLOWS and PASSTHRU REQUIREMENTS

(All values are in AcFt)

Target Passthru Monthly Target: 4,500 Salinity Relief Credit: 0 Effective:	4,500
Credit / -Deficit From Previous Month (Date Deficit Satisfied: )	-10,596
Wastewater Return Flow Credit (Effective: )	0
Required Passthru Target: 4,500 Reservoir Inflow: 153	153
Estuary Inflows (Measured at NCAT)	2,924
PassThru Surplus / -Deficit:	-7,826

Report Generated: 07/05/2000 at 8:47:11 AM

# Choke Canyon / Lake Corpus Christi Reservoir System Daily Status Report Report Date: July 6, 2000

## RESERVOIR STATISTICS

	Choke	r	Lake Co	rpus C	Christi		Combined Reservoir System				
Date	Elevation (Ft)	Volume (AcFt)	Perce Capa	-	Elevation (Ft)	Volume (AcFt)		Percent of Capacity	-		Percent of Capacity
FULL	220.5	695,271		100%	94.0	24	1,241	100	% 936,5	12	100%
07/06/1999	204.3	346,030	4	9.8%	90.3	174	4,743	72.4	% 520,7	73	55.6%
07/06/2000	199.6	271,360	3	9.0%	86.7	11'	7,799	48.8	% 389,1	59	41.6%
			Wea	ather R	Related In	forma	tion				
	Cho	ke Canyor	Reser	voir	La	ke Co	rpus (	Christi Res	ervoir	(	Combined
Date	Air Temp (°F)	Evapor (Acl		Rainfa (Inche				poration AcFt)	Rainfall (Inches)	Е	vaporation (AcFt)
07/05/2000	97		338	0	.00 9	5		343	0.00		681
MTD			1,912	0	.00			1,998	0.00		3,910

## STREAM FLOWS

Gauging Station	07/05/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	97	512
NRTT: Nueces River at Tilden, Texas	0	0
FRTT: Frio River at Tilden, Texas	0	1
SMTT: San Miguel Creek at Tilden, Texas	0	0
ARWT: Atascosa River at Whitsett, Texas	15	95
Release from Choke Canyon Reservoir	66	328
NCAT: Nueces River at Calallen, Texas	725	3,648
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	32	185

## ESTUARY INFLOWS and PASSTHRU REQUIREMENTS

(All values are in AcFt)

Target Passthru	
Monthly Target: 4,500	4,500
Salinity Relief Credit: 0 Effective:	
Credit / -Deficit From Previous Month (Date Deficit Satisfied: )	-10,596
Wastewater Return Flow Credit (Effective: )	0
Required Passthru	
Target: 4,500	185
Reservoir Inflow: 185	
Estuary Inflows (Measured at NCAT)	3,648
PassThru Surplus / -Deficit:	-7,133

Report Generated: 07/06/2000 at 8:39:37 AM

# Choke Canyon / Lake Corpus Christi Reservoir System Daily Status Report Report Date: July 7, 2000

## RESERVOIR STATISTICS

	Choke Canyon Reservoir					ike Cor	pus C	hristi	Comb	Combined Reservoir System		
Date	Elevation (Ft)	Volume (AcFt)		Percent of Capacity		vation Ft)	Volu (Ac	ume :Ft)	Percent of Capacity			Percent of Capacity
FULL	220.5	695,271		100%		94.0	241	1,241	100	% 936,5	12	100%
07/07/1999	204.3	345,686	4	9.7%		90.3	173	3,894	72.1	% 519,5	80	55.5%
07/07/2000	199.6	270,913	3	9.0%		86.6	116	5,510	48.3	% 387,4	23	41.4%
			Wea	ather I	Rela	ted Inf	orma	tion				
	Cho	ke Canyor	Reser	voir		Lal	ce Co	rpus (	Christi Res	ervoir		Combined
Date	Air Temp (°F)	Evapor (Acl				Air Temp (°F)		l .	poration AcFt)	Rainfall (Inches)	E	vaporation (AcFt)
07/06/2000	97		338 0		00.0	95			208	0.00		546
MTD			2,250	(	0.00				2,206	0.00		4,456

## STREAM FLOWS

Gauging Station	07/06/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	95	607
NRTT: Nueces River at Tilden, Texas	0	0
FRTT: Frio River at Tilden, Texas	0	1
SMTT: San Miguel Creek at Tilden, Texas	0	0
ARWT: Atascosa River at Whitsett, Texas	13	107
Release from Choke Canyon Reservoir	66	393
NCAT: Nueces River at Calallen, Texas	707	4,355
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	30	215

## ESTUARY INFLOWS and PASSTHRU REQUIREMENTS

(All values are in AcFt)

Target Passthru Monthly Target: 4,500 Salinity Relief Credit: 0 Effective:	4,500
Credit / -Deficit From Previous Month (Date Deficit Satisfied: )	-10,596
Wastewater Return Flow Credit (Effective: )	0
Required Passthru Target: 4,500 Reservoir Inflow: 215	215
Estuary Inflows (Measured at NCAT)	4,355
PassThru Surplus / -Deficit:	-6,456

Report Generated: 07/07/2000 at 8:43:45 AM

# Choke Canyon / Lake Corpus Christi Reservoir System Daily Status Report Report Date: July 8, 2000

## RESERVOIR STATISTICS

	Choke	r	Lake Co	rpus (	Christi		Combined Reservoir System				
Date	Elevation (Ft)	Volume (AcFt)	Perce Capa	-	Elevation (Ft)		ume cFt)	Percent of Capacity	_		Percent of Capacity
FULL	220.5	695,271		100%	94.0	24	1,241	100	% 936,5	12	100%
07/08/1999	204.3	345,686	4	9.7%	90.3	17	4,233	72.2	% 519,9	19	55.5%
07/08/2000	199.6	270,468	3	8.9%	86.0	11	5,797	48.0	% 386,2	65	41.2%
			Wea	ather R	Related In	forma	ation				
	Cho	ke Canyor	Reser	voir	L	ake Co	orpus	Christi Res	ervoir		Combined
Date	Air Temp	Evapor (Acl		Rainf (Inch		Air Temp (°F)		poration AcFt)	Rainfall (Inches)	E	vaporation (AcFt)
07/07/2000	99		363	0	0.00	8		357	0.00		720
MTD			2,613	0	0.00			2,563	0.00		5,176

## STREAM FLOWS

Gauging Station	07/07/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	97	705
NRTT: Nueces River at Tilden, Texas	0	0
FRTT: Frio River at Tilden, Texas	0	1
SMTT: San Miguel Creek at Tilden, Texas	0	0
ARWT: Atascosa River at Whitsett, Texas	11	118
Release from Choke Canyon Reservoir	66	459
NCAT: Nueces River at Calallen, Texas	697	5,052
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	32	247

## ESTUARY INFLOWS and PASSTHRU REQUIREMENTS

(All values are in AcFt)

Target Passthru  Monthly Target: 4,500 Salinity Relief Credit: 0 Effective:	4,500
Credit / -Deficit From Previous Month (Date Deficit Satisfied: )	-10,596
Wastewater Return Flow Credit (Effective: )	0
Required Passthru Target: 4,500 Reservoir Inflow: 247	247
Estuary Inflows (Measured at NCAT)	5,052
PassThru Surplus / -Deficit:	-5,791

Report Generated: 07/08/2000 at 8:33:02 AM

# Choke Canyon / Lake Corpus Christi Reservoir System Daily Status Report Report Date: July 9, 2000

## RESERVOIR STATISTICS

	Choke Canyon Reservoir					Lake Corpus Christi Reservoir						Combined Reservoir System		
Date	Elevation (Ft)	Volume (AcFt)		Percent of Capacity		vation Ft)	Volu (Ac		Percent of Capacity		olum AcFt)	- 1	Percent of Capacity	
FULL	220.5	695,271		100%		94.0	241	,241	100	% 9	36,51	12	100%	
07/09/1999	204.2	345,514	4	9.7%		90.4	175	5,083	72.6	% 5	20,59	97	55.6%	
07/09/2000	199.5	270,022	3	8.8%		86.5	114	1,518	47.5	% 3	84,54	10	41.1%	
			Wea	ather ]	Rela	ted Inf	orma	tion						
	Cho	ke Canyor	Reser	voir	Lake Corpus Christi Reservoi					ervoii	.	(	Combined	
Date	Air Temp	Evapor (Acl			ainfall A		e <b>mp</b> )		poration AcFt)	Rain (Incl		E	vaporation (AcFt)	
07/08/2000	100		372	372 0		99			380		0.00		752	
MTD			2,985	(	0.00				2,943		0.00		5,928	

## STREAM FLOWS

Gauging Station	07/08/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	87	792
NRTT: Nueces River at Tilden, Texas	0	0
FRTT: Frio River at Tilden, Texas	0	1
SMTT: San Miguel Creek at Tilden, Texas	0	0
ARWT: Atascosa River at Whitsett, Texas	10	128
Release from Choke Canyon Reservoir	66	524
NCAT: Nueces River at Calallen, Texas	738	5,790
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	22	269

## ESTUARY INFLOWS and PASSTHRU REQUIREMENTS

(All values are in AcFt)

Target Passthru Monthly Target: 4,500 Salinity Relief Credit: 0 Effective:	4,500
Credit / -Deficit From Previous Month (Date Deficit Satisfied: )	-10,596
Wastewater Return Flow Credit (Effective: )	0
Required Passthru Target: 4,500 Reservoir Inflow: 269	269
Estuary Inflows (Measured at NCAT)	5,790
PassThru Surplus / -Deficit:	-5,074

Report Generated: 07/09/2000 at 8:56:12 AM

# Choke Canyon / Lake Corpus Christi Reservoir System Daily Status Report Report Date: July 10, 2000

## RESERVOIR STATISTICS

	Choke Canyon Reservoir					Lake Corpus Christi Reservoir						Combined Reservoir System		
Date	Elevation (Ft)	Volume (AcFt)		Percent of Capacity		tion t)	Volu (Ac		Percent of Capacity	_		Percent of Capacity		
FULL	220.5	695,271		100%		94.0	241	,241	100	% 936,5	12	100%		
07/10/1999	204.2	345,342	4	9.7%		90.4	176	5,615	73.2	% 521,9	57	55.7%		
07/10/2000	199.5	269,578	3	8.8%		86.4	112	2,963	46.8	% 382,5	41	40.8%		
			Wea	ather F	Relate	d Info	orma	tion						
	Cho	ke Canyor	Reser	voir	Lake Corpus Christi Reservoir Comb					Combined				
Date	Air Temp (°F)	Evapor (Acl		Rainf (Inch		Air To (°F			poration AcFt)	Rainfall (Inches)	E	vaporation (AcFt)		
07/09/2000	97		388	388 0		96			386	0.00		774		
MTD			3,373	0	0.00				3,329	0.00		6,702		

## STREAM FLOWS

Gauging Station	07/09/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	85	877
NRTT: Nueces River at Tilden, Texas	0	0
FRTT: Frio River at Tilden, Texas	0	1
SMTT: San Miguel Creek at Tilden, Texas	0	0
ARWT: Atascosa River at Whitsett, Texas	9	137
Release from Choke Canyon Reservoir	66	590
NCAT: Nueces River at Calallen, Texas	719	6,509
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	20	289

## ESTUARY INFLOWS and PASSTHRU REQUIREMENTS

(All values are in AcFt)

Target Passthru  Monthly Target: 4,500 Salinity Relief Credit: 0 Effective:	4,500
Credit / -Deficit From Previous Month (Date Deficit Satisfied: )	-10,596
Wastewater Return Flow Credit (Effective: )	0
Required Passthru Target: 4,500 Reservoir Inflow: 289	289
Estuary Inflows (Measured at NCAT)	6,509
PassThru Surplus / -Deficit:	-4,376

Report Generated: 07/10/2000 at 8:40:16 AM

# Choke Canyon / Lake Corpus Christi Reservoir System Daily Status Report Report Date: July 11, 2000

## RESERVOIR STATISTICS

	Choke Canyon Reservoir					Lake Corpus Christi Reservoir						Combined Reservoir System		
Date	Elevation (Ft)	Volume (AcFt)	Perce Capa			evation   Volume   (Ft)   (AcFt)		Percent of Capacity	_	1	Percent of Capacity			
FULL	220.5	695,271		100%		94.0	241	,241	100	% 936,5	12	100%		
07/11/1999	204.2	344,998	4	9.6%		90.6	178	3,495	74.0	% 523,4	93	55.9%		
07/11/2000	199.5	269,133	3	8.7%		86.3	111	,416	46.2	% 380,5	49	40.6%		
			Wea	ather R	Relate	d Info	orma	tion						
	Cho	ke Canyor	Reser	voir	Lake Corpus Christi Reservoir Comb					Combined				
Date	Air Temp (°F)	Evapor (Ac		Rainf (Inch		Air Temp I			poration AcFt)	Rainfall (Inches)	E	vaporation (AcFt)		
07/10/2000	99		328	328 0		98			392	0.00		720		
MTD			3,701	0	0.00				3,721	0.00		7,422		

## STREAM FLOWS

Gauging Station	07/10/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	85	963
NRTT: Nueces River at Tilden, Texas	0	0
FRTT: Frio River at Tilden, Texas	0	1
SMTT: San Miguel Creek at Tilden, Texas	0	0
ARWT: Atascosa River at Whitsett, Texas	10	147
Release from Choke Canyon Reservoir	66	655
NCAT: Nueces River at Calallen, Texas	717	7,225
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	20	308

## ESTUARY INFLOWS and PASSTHRU REQUIREMENTS

(All values are in AcFt)

Target Passthru	
Monthly Target: 4,500	3,375
Salinity Relief Credit: 1,125 Effective: 07/11/2000	
Credit / -Deficit From Previous Month (Date Deficit Satisfied: )	-10,596
Wastewater Return Flow Credit (Effective: )	0
Required Passthru	
Target: 3,375	308
Reservoir Inflow: 308	
Estuary Inflows (Measured at NCAT)	7,225
PassThru Surplus / -Deficit:	-3,679

Report Generated: 07/11/2000 at 8:47:49 AM

# Choke Canyon / Lake Corpus Christi Reservoir System Daily Status Report Report Date: July 12, 2000

## RESERVOIR STATISTICS

	Choke	r	Lake Co	pus C	Christi		Combined Reservoir System				
Date	Elevation (Ft)	Volume (AcFt)	Perce Capa		Elevation (Ft)		ume EFt)	Percent of Capacity	_		Percent of Capacity
FULL	220.5	695,271		100%	94.0	241	1,241	100	% 936,5	12	100%
07/12/1999	204.2	345,342	4	9.7%	90.6	179	9,352	74.3	% 524,6	94	56.0%
07/12/2000	199.4	268,690	3	8.6%	86.2	110	),576	45.8	% 379,2	66	40.5%
			Wea	ather R	Related Inf	orma	tion				
	Cho	ke Canyor	Reser	voir	Lake Corpus Christi Reservoir Combin					Combined	
Date	Air Temp	Evapor (Acl		Rainf (Inche		Air Temp (°F)		poration AcFt)	Rainfall (Inches)	E	vaporation (AcFt)
07/11/2000	100		388	0	.00 98	3		399	0.00		787
MTD			4,089	0	.00			4,120	0.00		8,209

## STREAM FLOWS

Gauging Station	07/11/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	83	1,046
NRTT: Nueces River at Tilden, Texas	0	0
FRTT: Frio River at Tilden, Texas	1	1
SMTT: San Miguel Creek at Tilden, Texas	0	0
ARWT: Atascosa River at Whitsett, Texas	9	156
Release from Choke Canyon Reservoir	66	721
NCAT: Nueces River at Calallen, Texas	671	7,896
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	18	327

## ESTUARY INFLOWS and PASSTHRU REQUIREMENTS

(All values are in AcFt)

Target Passthru	
Monthly Target: 4,500	3,375
Salinity Relief Credit: 1,125 Effective: 07/11/2000	
Credit / -Deficit From Previous Month (Date Deficit Satisfied: )	-10,596
Wastewater Return Flow Credit (Effective: )	0
Required Passthru	
Target: 3,375	327
Reservoir Inflow: 327	
Estuary Inflows (Measured at NCAT)	7,896
PassThru Surplus / -Deficit:	-3,026

Report Generated: 07/12/2000 at 8:45:25 AM

# Choke Canyon / Lake Corpus Christi Reservoir System Daily Status Report Report Date: July 13, 2000

## RESERVOIR STATISTICS

	Choke Canyon Reservoir				La	pus C	hristi	Comb	Combined Reservoir System			
Date	Elevation (Ft)	Volume (AcFt)	Percent of Capacity			Elevation (Ft) Volume (AcFt)			Percent of Capacity	_		Percent of Capacity
FULL	220.5	695,271		100%		94.0	241	,241	100	% 936,5	12	100%
07/13/1999	204.2	344,826	4	9.6%		90.6	179	74.3		% 524,1	78	56.0%
07/13/2000	199.4	268,246	3	8.6%		86.1 109,4		9,461	45.4	% 377,7	07	40.3%
			Wea	ather F	Relat	ed Inf	orma	tion				
	Cho	ke Canyor	Reser	voir	Lake Corpus Christi Reservoir Comb					Combined		
Date	Air Temp (°F)	Evapor (Acl		Rainf (Inch		Air Temp (°F)		<u> </u>		Rainfall (Inches)	E	vaporation (AcFt)
07/12/2000	103		447	0	0.00	100	)		454	0.00		901
MTD			4,536	0	0.00				4,574	0.00		9,110

## STREAM FLOWS

Gauging Station	07/12/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	81	1,127
NRTT: Nueces River at Tilden, Texas	0	0
FRTT: Frio River at Tilden, Texas	0	1
SMTT: San Miguel Creek at Tilden, Texas	0	0
ARWT: Atascosa River at Whitsett, Texas	9	165
Release from Choke Canyon Reservoir	66	786
NCAT: Nueces River at Calallen, Texas	679	8,575
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	16	343

## ESTUARY INFLOWS and PASSTHRU REQUIREMENTS

(All values are in AcFt)

Target Passthru	
Monthly Target: 4,500	3,375
Salinity Relief Credit: 1,125 Effective: 07/11/2000	
Credit / -Deficit From Previous Month (Date Deficit Satisfied: )	-10,596
Wastewater Return Flow Credit (Effective: )	0
Required Passthru	
Target: 3,375	343
Reservoir Inflow: 343	
Estuary Inflows (Measured at NCAT)	8,575
PassThru Surplus / -Deficit:	-2,364

Report Generated: 07/13/2000 at 8:22:13 AM

# Choke Canyon / Lake Corpus Christi Reservoir System Daily Status Report Report Date: July 14, 2000

## RESERVOIR STATISTICS

	Choke Canyon Reservoir				Lake (	pus C	hristi	Comb	Combined Reservoir System			
Date	Elevation (Ft)	Volume (AcFt)	Perce Capa	-	Elevatio (Ft)	n	Volu (Ac		Percent of Capacity	-		Percent of Capacity
FULL	220.5	695,271		100%	94	1.0	241	,241 100		% 936,5	12	100%
07/14/1999	204.2	344,483	49.5%		90	).6	178	3,495	74.0	% 522,9	78	55.8%
07/14/2000	199.4	267,803	3	8.5%	86	86.0 108,35		3,350	44.9	% 376,1	53	40.2%
			Wea	ather R	Related 1	Info	orma	tion				
	Cho	ke Canyor	Reser	voir	Lake Corpus Christi Reservoir Co					Combined		
Date	Air Temp	Evapor (Acl		Rainf (Inch		Air Temp (°F)		Evaporation (AcFt)		Rainfall (Inches)	E	vaporation (AcFt)
07/13/2000	104		387	0	.00	10	1		379	0.00		766
MTD			4,923	0	0.00				4,953	0.00		9,876

## STREAM FLOWS

Gauging Station	07/13/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	81	1,209
NRTT: Nueces River at Tilden, Texas	0	0
FRTT: Frio River at Tilden, Texas	0	2
SMTT: San Miguel Creek at Tilden, Texas	0	0
ARWT: Atascosa River at Whitsett, Texas	8	173
Release from Choke Canyon Reservoir	66	852
NCAT: Nueces River at Calallen, Texas	705	9,280
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	16	359

## ESTUARY INFLOWS and PASSTHRU REQUIREMENTS

(All values are in AcFt)

Target Passthru Monthly Target: 4,500 Salinity Relief Credit: 1,125 Effective: 07/11/2000	3,375
Credit / -Deficit From Previous Month (Date Deficit Satisfied: )	-10,596
Wastewater Return Flow Credit (Effective: )	0
Required Passthru Target: 3,375 Reservoir Inflow: 359	359
Estuary Inflows (Measured at NCAT)	9,280
PassThru Surplus / -Deficit:	-1,675

Report Generated: 07/14/2000 at 8:20:13 AM

# Choke Canyon / Lake Corpus Christi Reservoir System Daily Status Report Report Date: July 15, 2000

## RESERVOIR STATISTICS

	Choke Canyon Reservoir				Lake Co	Christi		Combined Reservoir System			
Date	Elevation (Ft)	Volume (AcFt)	Perce Capa		Elevation (Ft)		ume EFt)	Percent of Capacity	_		Percent of Capacity
FULL	220.5	695,271		100%	94.0	24	1,241	100	% 936,5	12	100%
07/15/1999	204.2	344,140	4	9.5%	90.6	178	8,666	74.1	% 522,8	06	55.8%
07/15/2000	199.4	267,361	3	8.5%	86.0	86.0 107,382		44.5	% 374,743		40.0%
			Wea	ather R	elated In	forma	tion				
	Cho	ke Canyor	Reser	voir	Lake Corpus Christi Reservoir Com					Combined	
Date	Air Temp	Evapor (Acl		Rainfa (Inche		Air Temp		poration AcFt)	Rainfall (Inches)	E	vaporation (AcFt)
07/14/2000	104		258	0.	.00 10	)3		377	0.00		635
MTD			5,181	0.	.00			5,330	0.00		10,511

## STREAM FLOWS

Gauging Station	07/14/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	79	1,288
NRTT: Nueces River at Tilden, Texas	0	0
FRTT: Frio River at Tilden, Texas	0	2
SMTT: San Miguel Creek at Tilden, Texas	0	0
ARWT: Atascosa River at Whitsett, Texas	8	180
Release from Choke Canyon Reservoir	66	917
NCAT: Nueces River at Calallen, Texas	707	9,987
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	14	373

## ESTUARY INFLOWS and PASSTHRU REQUIREMENTS

(All values are in AcFt)

Target Passthru	
Monthly Target: 4,500	3,375
Salinity Relief Credit: 1,125 Effective: 07/11/2000	
Credit / -Deficit From Previous Month (Date Deficit Satisfied: )	-10,596
Wastewater Return Flow Credit (Effective: )	0
Required Passthru	
Target: 3,375	373
Reservoir Inflow: 373	
Estuary Inflows (Measured at NCAT)	9,987
PassThru Surplus / -Deficit:	-983

Report Generated: 07/15/2000 at 8:33:24 AM

# Choke Canyon / Lake Corpus Christi Reservoir System Daily Status Report Report Date: July 16, 2000

## RESERVOIR STATISTICS

	Choke Canyon Reservoir				Lake Cor	pus C	hristi		Combined Reservoir System		
Date	Elevation (Ft)	Volume (AcFt)	Percent of Capacity		Elevation (Ft)	Volu (Ac		Percent of Capacity	_		Percent of Capacity
FULL	220.5	695,271	100%		94.0	241	1,241	100	% 936,5	12	100%
07/16/1999	204.1	343,626	4	9.4%	90.6	178	3,495	74.0	% 522,1	21	55.8%
07/16/2000	199.3	266,919	38.4%		85.9	85.9 106,69		44.2	% 373,614		39.9%
			Wea	ather R	elated Inf	orma	tion				
	Cho	ke Canyor	Reser	voir	Lake Corpus Christi Reservoir Co					Combined	
Date	Air Temp	Evapor (Acl		Rainfa (Inche		Air Temp		poration AcFt)	Rainfall (Inches)	E	vaporation (AcFt)
07/15/2000	106		412	0.	00 10:	5		384	0.00		796
MTD			5,593	0.	00			5,714	0.00		11,307

## STREAM FLOWS

Gauging Station	07/15/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	79	1,368
NRTT: Nueces River at Tilden, Texas	0	0
FRTT: Frio River at Tilden, Texas	1	3
SMTT: San Miguel Creek at Tilden, Texas	0	0
ARWT: Atascosa River at Whitsett, Texas	7	187
Release from Choke Canyon Reservoir	66	983
NCAT: Nueces River at Calallen, Texas	570	10,556
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	14	388

## ESTUARY INFLOWS and PASSTHRU REQUIREMENTS

(All values are in AcFt)

Target Passthru	
Monthly Target: 4,500	3,375
Salinity Relief Credit: 1,125 Effective: 07/11/2000	
Credit / -Deficit From Previous Month (Date Deficit Satisfied: )	-10,596
Wastewater Return Flow Credit (Effective: )	0
Required Passthru	
Target: 3,375	388
Reservoir Inflow: 388	
Estuary Inflows (Measured at NCAT)	10,556
PassThru Surplus / -Deficit:	-427

Report Generated: 07/16/2000 at 8:49:02 AM

# Choke Canyon / Lake Corpus Christi Reservoir System Daily Status Report Report Date: July 17, 2000

## RESERVOIR STATISTICS

	Choke	r	Lake Co	rpus	Christi		Combined Reservoir System				
Date	Elevation (Ft)	Volume (AcFt)	Perce Capa	-	Elevatior (Ft)		lume cFt)	Percent of Capacity	_		Percent of Capacity
FULL	220.5	695,271		100%	94.	94.0 241		100	% 936,5	12	100%
07/17/1999	204.1	343,112	4	9.3%	90.	90.6 178,495		74.0	% 521,6	07	55.7%
07/17/2000	199.3	266,625	3	8.3%	85.	10	06,011	43.9	% 372,6	36	39.8%
			Wea	ather R	Related Ir	form	ation				
	Cho	ke Canyor	Reser	voir	L	ake C	orpus	orpus Christi Reservoir Combin			
Date	Air Temp (°F)	Evapor (Ac		on Rainfall (Inches)		. r		poration AcFt)	Rainfall (Inches)	E	vaporation (AcFt)
07/16/2000	104		394	0	0.00 1	01		421	0.00		815
MTD			5,987	0	0.00			6,135	0.00		12,122

## STREAM FLOWS

Gauging Station	07/16/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	77	1,445
NRTT: Nueces River at Tilden, Texas	0	0
FRTT: Frio River at Tilden, Texas	0	3
SMTT: San Miguel Creek at Tilden, Texas	0	0
ARWT: Atascosa River at Whitsett, Texas	7	194
Release from Choke Canyon Reservoir	66	1,048
NCAT: Nueces River at Calallen, Texas	159	10,715
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	12	400

## ESTUARY INFLOWS and PASSTHRU REQUIREMENTS

(All values are in AcFt)

Target Passthru  Monthly Target: 4,500 Salinity Relief Credit: 1,125 Effective: 07/11/2000	3,375
Credit / -Deficit From Previous Month (Date Deficit Satisfied: 07/17/2000)	-10,596
Wastewater Return Flow Credit (Effective: 07/17/0200)	500
Required Passthru Target: 3,375 Reservoir Inflow: 400	400
Estuary Inflows (Measured at NCAT)	10,715
PassThru Surplus / -Deficit:	219

Report Generated: 07/17/2000 at 8:24:58 AM

## Choke Canyon / Lake Corpus Christi Reservoir System Daily Status Report Report Date: July 18, 2000

## RESERVOIR STATISTICS

	Choke Canyon Reservoir				La	ike Cor	pus C	hristi		Combined Reservoir System		
Date	Elevation (Ft)	Volume (AcFt)		Percent of Capacity		vation Ft)	Volu (Ac		Percent of Capacity			Percent of Capacity
FULL	220.5	695,271		100%		94.0 241,241		,241	100	% 936,5	12	100%
07/18/1999	204.1	342,940	4	49.3%		90.6	179,180		74.3	% 522,1	20	55.8%
07/18/2000	199.3	266,037	3	8.3%	85.8		105	5,466	43.7	% 371,5	03	39.7%
			Wea	ather I	Rela	ted Inf	orma	tion				
	Cho	ke Canyor	Reser	voir	Lake Corpus Christi Reser					ervoir		Combined
Date	Air Temp	Evapor (Acl							poration AcFt)	Rainfall (Inches)	E	vaporation (AcFt)
07/17/2000	100		376	376 0.		98			380	0.00		756
MTD			6,363	(	0.00				6,515	0.00		12,878

## STREAM FLOWS

Gauging Station	07/17/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	77	1,522
NRTT: Nueces River at Tilden, Texas	0	0
FRTT: Frio River at Tilden, Texas	0	3
SMTT: San Miguel Creek at Tilden, Texas	0	0
ARWT: Atascosa River at Whitsett, Texas	6	200
Release from Choke Canyon Reservoir	66	1,114
NCAT: Nueces River at Calallen, Texas	52	10,767
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	12	412

## **ESTUARY INFLOWS and PASSTHRU REQUIREMENTS** (All values are in AcFt)

Target Passthru Monthly Target: 4,500 Salinity Relief Credit: 1,125 Effective: 07/11/2000	3,375
Credit / -Deficit From Previous Month (Date Deficit Satisfied: 07/17/2000)	-10,596
Wastewater Return Flow Credit (Effective: 07/17/0200)	500
Required Passthru Target: 3,375 Reservoir Inflow: 412	412
Estuary Inflows (Measured at NCAT)	10,767
PassThru Surplus / -Deficit:	259

Report Generated: 07/18/2000 at 8:23:47 AM

# Choke Canyon / Lake Corpus Christi Reservoir System Daily Status Report Report Date: July 19, 2000

## RESERVOIR STATISTICS

	Choke	r	Lake	pus C	hristi	Comb	Combined Reservoir System					
Date	Elevation (Ft)	Volume (AcFt)	Perce Capa		Elevati (Ft)		Volu (Ac		Percent of Capacity	_		Percent of Capacity
FULL	220.5	695,271		100%	9	94.0 241,241		100	% 936,5	12	100%	
07/19/1999	204.1	343,112	4	19.3%	ç	90.6	179,180		74.3	% 522,2	92	55.8%
07/19/2000	199.2	265,157	3	88.1%	85.		104	,923	43.5	% 370,0	80	39.5%
			Wea	ather R	Related	Info	orma	tion				
	Cho	ke Canyor	Reser	voir		Lak	ce Co	rpus (	Christi Res	ervoir		Combined
Date	Air Temp (°F)	Evapor (Acl				. r			poration AcFt)	Rainfall (Inches)	E	vaporation (AcFt)
07/18/2000	101		376	376 0		100	)		355	0.00		731
MTD			6,739	0	0.00				6,870	0.00		13,609

## STREAM FLOWS

Gauging Station	07/18/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	77	1,600
NRTT: Nueces River at Tilden, Texas	0	0
FRTT: Frio River at Tilden, Texas	0	3
SMTT: San Miguel Creek at Tilden, Texas	0	0
ARWT: Atascosa River at Whitsett, Texas	6	207
Release from Choke Canyon Reservoir	66	1,179
NCAT: Nueces River at Calallen, Texas	20	10,786
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	12	424

## ESTUARY INFLOWS and PASSTHRU REQUIREMENTS

(All values are in AcFt)

Target Passthru  Monthly Target: 4,500 Salinity Relief Credit: 1,125 Effective: 07/11/2000	3,375
Credit / -Deficit From Previous Month (Date Deficit Satisfied: 07/17/2000)	-10,596
Wastewater Return Flow Credit (Effective: 07/17/0200)	500
Required Passthru Target: 3,375 Reservoir Inflow: 424	424
Estuary Inflows (Measured at NCAT)	10,786
PassThru Surplus / -Deficit:	267

Report Generated: 07/19/2000 at 8:21:40 AM

# Choke Canyon / Lake Corpus Christi Reservoir System Daily Status Report Report Date: July 20, 2000

## RESERVOIR STATISTICS

	Choke Canyon Reservoir					Lake Corpus Christi Reservoir						Combined Reservoir System		
Date	Elevation (Ft)	Volume (AcFt)		Percent of Capacity				ration Ft)	Volu (Ac	ume :Ft)	Percent of Capacity	-		Percent of Capacity
FULL	220.5	695,271		100%		94.0	241	1,241	100	% 936,	512	100%		
07/20/1999	204.1	342,769	4	9.3%		90.6	6 179,352		74.3	% 522,	121	55.8%		
07/20/2000	199.2	265,010	3	8.1%		85.7	104	1,382	43.3	% 369,3	392	39.4%		
			Wea	ather F	Relat	ed Info	orma	tion						
	Cho	ke Canyor	Reser	voir		Lal	ce Co	rpus (	Christi Res	ervoir		Combined		
Date	Air Temp (°F)	Evapor (Acl		Rainfall (Inches)		Air Temp		l .	poration AcFt)	Rainfall (Inches)		vaporation (AcFt)		
07/19/2000	104		384	384 0.		102	2		393	0.00		777		
MTD			7,123	0	0.00				7,263	0.00		14,386		

## STREAM FLOWS

Gauging Station	07/19/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	75	1,675
NRTT: Nueces River at Tilden, Texas	0	0
FRTT: Frio River at Tilden, Texas	0	3
SMTT: San Miguel Creek at Tilden, Texas	0	0
ARWT: Atascosa River at Whitsett, Texas	6	213
Release from Choke Canyon Reservoir	66	1,245
NCAT: Nueces River at Calallen, Texas	28	10,814
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	10	433

## ESTUARY INFLOWS and PASSTHRU REQUIREMENTS

(All values are in AcFt)

Target Passthru Monthly Target: 4,500 Salinity Relief Credit: 1,125 Effective: 07/11/2000	3,375
Credit / -Deficit From Previous Month (Date Deficit Satisfied: 07/17/2000)	-10,596
Wastewater Return Flow Credit (Effective: 07/17/0200)	500
Required Passthru Target: 3,375 Reservoir Inflow: 433	433
Estuary Inflows (Measured at NCAT)	10,814
PassThru Surplus / -Deficit:	285

Report Generated: 07/20/2000 at 8:41:19 AM

# Choke Canyon / Lake Corpus Christi Reservoir System Daily Status Report Report Date: July 21, 2000

## RESERVOIR STATISTICS

	Choke Canyon Reservoir				Lake (	pus C	hristi		Combined Reservoir System			
Date	Elevation (Ft)	Volume (AcFt)	Percent of Capacity		Elevation (Ft)				Percent of Capacity	_		Percent of Capacity
FULL	220.5	695,271		100%	94	4.0	241	,241	100	% 936,5	12	100%
07/21/1999	204.6	342,427	4	9.3%	90	0.6	179,352		74.3	% 521,7	79	55.7%
07/21/2000	199.2	264,425	3	8.0%	85.7		103	3,574	42.9	% 367,9	99	39.3%
			Wea	ather R	Related	Info	orma	tion				
	Cho	ke Canyor	Reser	voir	Lake Corpus Christi Reservoir Comb					Combined		
Date	Air Temp (°F)	Evapor (Acl				Air Temp (°F)		<u>r</u>		Rainfall (Inches)	E	vaporation (AcFt)
07/20/2000	105		452	0	0.00	103	3		414	0.00		866
MTD			7,575	0	0.00				7,677	0.00		15,252

## STREAM FLOWS

Gauging Station	07/20/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	75	1,751
NRTT: Nueces River at Tilden, Texas	0	0
FRTT: Frio River at Tilden, Texas	0	3
SMTT: San Miguel Creek at Tilden, Texas	0	0
ARWT: Atascosa River at Whitsett, Texas	6	219
Release from Choke Canyon Reservoir	66	1,310
NCAT: Nueces River at Calallen, Texas	26	10,840
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	10	443

## ESTUARY INFLOWS and PASSTHRU REQUIREMENTS

(All values are in AcFt)

Target Passthru Monthly Target: 4,500 Salinity Relief Credit: 1,125 Effective: 07/11/2000	3,375
Credit / -Deficit From Previous Month (Date Deficit Satisfied: 07/17/2000)	-10,596
Wastewater Return Flow Credit (Effective: 07/17/0200)	500
Required Passthru Target: 3,375 Reservoir Inflow: 443	443
Estuary Inflows (Measured at NCAT)	10,840
PassThru Surplus / -Deficit:	301

Report Generated: 07/21/2000 at 8:24:13 AM

# Choke Canyon / Lake Corpus Christi Reservoir System Daily Status Report Report Date: July 22, 2000

## RESERVOIR STATISTICS

	Choke Canyon Reservoir				La	pus C	hristi	Comb	Combined Reservoir System			
Date	Elevation (Ft)	Volume (AcFt)	Percent of Capacity			ration Volume (AcFt)		Percent of Capacity	_		Percent of Capacity	
FULL	220.5	695,271		100%		94.0	241	,241 10		% 936,5	512	100%
07/22/1999	204.1	342,256	4	9.2%		90.6	179,867		74.6	% 522,1	23	55.8%
07/22/2000	199.1	263,840	3	7.9%	85.6		103	3,039	42.7	% 366,8	379	39.2%
			Wea	ather I	Relat	ed Info	orma	tion				
	Cho	ke Canyor	Reser	voir	Lake Corpus Christi Reservoir					Combined		
Date	Air Temp (°F)	Evapor (Acl		Rainf (Inch						Rainfall (Inches)	E	vaporation (AcFt)
07/21/2000	103		374	374 0.0		100		389		0.00		763
MTD			7,949	C	0.00				8,066	0.00		16,015

## STREAM FLOWS

Gauging Station	07/21/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	75	1,826
NRTT: Nueces River at Tilden, Texas	0	0
FRTT: Frio River at Tilden, Texas	0	3
SMTT: San Miguel Creek at Tilden, Texas	0	0
ARWT: Atascosa River at Whitsett, Texas	6	225
Release from Choke Canyon Reservoir	66	1,376
NCAT: Nueces River at Calallen, Texas	0	10,840
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	10	453

## ESTUARY INFLOWS and PASSTHRU REQUIREMENTS

(All values are in AcFt)

Target Passthru	
Monthly Target: 4,500	3,375
Salinity Relief Credit: 1,125 Effective: 07/11/2000	
Credit / -Deficit From Previous Month (Date Deficit Satisfied: 07/17/2000)	-10,596
Wastewater Return Flow Credit (Effective: 07/17/0200)	500
Required Passthru	
Target: 3,375	453
Reservoir Inflow: 453	
Estuary Inflows (Measured at NCAT)	10,840
PassThru Surplus / -Deficit:	291

Report Generated: 07/22/2000 at 8:30:07 AM

# Choke Canyon / Lake Corpus Christi Reservoir System Daily Status Report Report Date: July 23, 2000

## RESERVOIR STATISTICS

	Choke Canyon Reservoir				Lake Cor	pus C	Christi	Comb	Combined Reservoir System		
Date	Elevation (Ft)	Volume (AcFt)	Percent of Capacity		Elevation (Ft)			Percent of Capacity	-		Percent of Capacity
FULL	220.5	695,271		100%	94.0	241	1,241	100	% 936,5	12	100%
07/23/1999	204.0	341,914	4	9.2%	90.6	179,695		74.5	% 521,6	09	55.7%
07/23/2000	199.1	263,402	37.9%		85.6	102	2,638	42.5	% 366,0	40	39.1%
			Wea	ather R	elated Inf	orma	tion				
	Cho	ke Canyon	Reser	voir	Lake Corpus Christi Reservoir Com					Combined	
Date	Air Temp (°F)	Evapor (Acl		Rainfa (Inche			l .	poration AcFt)	Rainfall (Inches)	E	vaporation (AcFt)
07/22/2000	102		399	0.	.00 99		342		0.00		741
MTD			8,348	0.	.00			8,408	0.00		16,756

## STREAM FLOWS

Gauging Station	07/22/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	75	1,902
NRTT: Nueces River at Tilden, Texas	0	0
FRTT: Frio River at Tilden, Texas	0	3
SMTT: San Miguel Creek at Tilden, Texas	0	0
ARWT: Atascosa River at Whitsett, Texas	5	230
Release from Choke Canyon Reservoir	66	1,441
NCAT: Nueces River at Calallen, Texas	0	10,840
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	10	463

## ESTUARY INFLOWS and PASSTHRU REQUIREMENTS

(All values are in AcFt)

Target Passthru	2.25
Monthly Target: 4,500	3,375
Salinity Relief Credit: 1,125 Effective: 07/11/2000	
Credit / -Deficit From Previous Month (Date Deficit Satisfied: 07/17/2000)	-10,596
Wastewater Return Flow Credit (Effective: 07/17/0200)	500
Required Passthru	
Target: 3,375	463
Reservoir Inflow: 463	
Estuary Inflows (Measured at NCAT)	10,840
PassThru Surplus / -Deficit:	281

Report Generated: 07/23/2000 at 8:23:50 AM

# Choke Canyon / Lake Corpus Christi Reservoir System Daily Status Report Report Date: July 24, 2000

## RESERVOIR STATISTICS

	Choke Canyon Reservoir				Lake Co	rpus C	Christi		Combined Reservoir System		
Date	Elevation (Ft)	Volume (AcFt)	Percent of Capacity		Elevation (Ft)	on Volume (AcFt)		Percent of Capacity	-		Percent of Capacity
FULL	220.5	695,271		100%	94.0	24	1,241	100	% 936,5	12	100%
07/24/1999	204.0	341,743	4	9.2%	90.6	179	9,180	74.3	% 520,9	23	55.6%
07/24/2000	199.1	263,110	3	7.8%	85.6	85.6 101,9		42.3	% 365,084		39.0%
			Wea	ather R	Related In	forma	tion				
	Cho	ke Canyor	Reser	voir	Lake Corpus Christi Reservoir Co					Combined	
Date	Air Temp	Evapor (Acl		Rainfa (Inche			np Evaporation (AcFt)		Rainfall (Inches)	E	vaporation (AcFt)
07/23/2000	104		365	0	.00 10	)1		378	0.00		743
MTD			8,713	0	.00			8,786	0.00		17,499

## STREAM FLOWS

Gauging Station	07/23/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	75	1,977
NRTT: Nueces River at Tilden, Texas	0	0
FRTT: Frio River at Tilden, Texas	0	3
SMTT: San Miguel Creek at Tilden, Texas	0	0
ARWT: Atascosa River at Whitsett, Texas	5	236
Release from Choke Canyon Reservoir	66	1,507
NCAT: Nueces River at Calallen, Texas	0	10,840
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	10	473

## ESTUARY INFLOWS and PASSTHRU REQUIREMENTS

(All values are in AcFt)

Target Passthru	
Monthly Target: 4,500	3,375
Salinity Relief Credit: 1,125 Effective: 07/11/2000	
Credit / -Deficit From Previous Month (Date Deficit Satisfied: 07/17/2000)	-10,596
Wastewater Return Flow Credit (Effective: 07/17/0200)	500
Required Passthru	
Target: 3,375	473
Reservoir Inflow: 473	
Estuary Inflows (Measured at NCAT)	10,840
PassThru Surplus / -Deficit:	271

Report Generated: 07/24/2000 at 8:25:04 AM

# Choke Canyon / Lake Corpus Christi Reservoir System Daily Status Report Report Date: July 25, 2000

## RESERVOIR STATISTICS

	Choke Canyon Reservoir				Lake Cor	pus C	hristi		Combined Reservoir System		
Date	Elevation (Ft)	Volume (AcFt)	Perce Capa	-	Elevation (Ft)	Volu (Ac		Percent of Capacity	_		Percent of Capacity
FULL	220.5	695,271		100%	94.0	241	1,241	100	% 936,5	12	100%
07/25/1999	204.0	341,401	4	19.1%	90.6	179	9,009	74.2	% 520,4	10	55.6%
07/25/2000	199.0	262,528	3	37.8%	85.5	85.5 101,049		41.9	% 363,577		38.8%
			Wea	ather R	elated Info	orma	tion				
	Cho	ke Canyor	Reser	voir	Lake Corpus Christi Reservoir C					Combined	
Date	Air Temp	Evapor (Acl		Rainfa (Inche		Air Temp		poration AcFt)	Rainfall (Inches)	E	vaporation (AcFt)
07/24/2000	102		382	0.	.00 100	)		330	0.00		712
MTD			9,095	0.	.00			9,116	0.00		18,211

## STREAM FLOWS

Gauging Station	07/24/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	75	2,052
NRTT: Nueces River at Tilden, Texas	0	0
FRTT: Frio River at Tilden, Texas	0	3
SMTT: San Miguel Creek at Tilden, Texas	0	0
ARWT: Atascosa River at Whitsett, Texas	5	241
Release from Choke Canyon Reservoir	66	1,572
NCAT: Nueces River at Calallen, Texas	8	10,848
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	10	483

## ESTUARY INFLOWS and PASSTHRU REQUIREMENTS

(All values are in AcFt)

Target Passthru  Marthly Target 4 500	2 275
Monthly Target: 4,500	3,375
Salinity Relief Credit: 1,125 Effective: 07/11/2000	
Credit / -Deficit From Previous Month (Date Deficit Satisfied: 07/17/2000)	-10,596
Wastewater Return Flow Credit (Effective: 07/17/0200)	500
Required Passthru	
Target: 3,375	483
Reservoir Inflow: 483	
Estuary Inflows (Measured at NCAT)	10,848
PassThru Surplus / -Deficit:	269

Report Generated: 07/25/2000 at 8:36:00 AM

# Choke Canyon / Lake Corpus Christi Reservoir System Daily Status Report Report Date: July 26, 2000

## RESERVOIR STATISTICS

	Choke Canyon Reservoir				Lak	pus C	hristi	Comb	Combined Reservoir System			
Date	Elevation (Ft)	Volume (AcFt)	Perce Capa		Eleva (F		Volu (Ac		Percent of Capacity	_		Percent of Capacity
FULL	220.5	695,271		100%		94.0	241	,241 1009		% 936,5	12	100%
07/26/1999	204.0	340,548	4	9.0%		90.6	178	5,838 74.1		% 519,3	86	55.5%
07/26/2000	199.0	262,091	3	7.7%		85.4	100,261		41.6	% 362,3	52	38.7%
			Wea	ather F	Relate	d Info	orma	tion				
	Cho	ke Canyor	Reser	voir	Lake Corpus Christi Reservoir Con					Combined		
Date	Air Temp (°F)	Evapor (Ac				Air Temp (°F)			poration AcFt)	Rainfall (Inches)	E	vaporation (AcFt)
07/25/2000	102		398	398 0		100	)		358	0.00		756
MTD			9,493	0	0.00				9,474	0.00		18,967

## STREAM FLOWS

Gauging Station	07/25/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	75	2,128
NRTT: Nueces River at Tilden, Texas	0	0
FRTT: Frio River at Tilden, Texas	0	3
SMTT: San Miguel Creek at Tilden, Texas	0	0
ARWT: Atascosa River at Whitsett, Texas	4	245
Release from Choke Canyon Reservoir	66	1,638
NCAT: Nueces River at Calallen, Texas	56	10,904
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	10	493

## ESTUARY INFLOWS and PASSTHRU REQUIREMENTS

(All values are in AcFt)

Target Passthru  Monthly Target: 4,500  Salinity Relief Credit: 1,125 Effective: 07/11/2000	3,375
Credit / -Deficit From Previous Month (Date Deficit Satisfied: 07/17/2000)	-10,596
Wastewater Return Flow Credit (Effective: 07/17/0200)	500
Required Passthru Target: 3,375 Reservoir Inflow: 493	493
Estuary Inflows (Measured at NCAT)	10,904
PassThru Surplus / -Deficit:	315

Report Generated: 07/26/2000 at 8:49:47 AM

# Choke Canyon / Lake Corpus Christi Reservoir System Daily Status Report Report Date: July 27, 2000

## RESERVOIR STATISTICS

	Choke Canyon Reservoir				Lake Corpus Christi Reservoir						Combined Reservoir System		
Date	Elevation (Ft)	Volume (AcFt)	Perce Capa			ration Ft)	Volu (Ac		Percent of Capacity	-		Percent of Capacity	
FULL	220.5	695,271		100%		94.0	241	1,241	100	% 936	512	100%	
07/27/1999	203.9	340,377	4	9.0%		90.6	178	3,495	74.0	% 518	872	55.4%	
07/27/2000	199.0	261,510	3	7.6%		85.4	85.4 99,738		41.3	% 361	248	38.6%	
			Wea	ather F	Relat	ed Inf	orma	tion					
	Cho	ke Canyor	Reser	voir		Lake Corpus Christi Reservoir Coml					Combined		
Date	Air Temp (°F)	Evapor (Acl				Air Temp		l .	poration AcFt)	Rainfal (Inches	- 1	Evaporation (AcFt)	
07/26/2000	101		304	304 0		99			357	0.0	0	661	
MTD			9,797	0	0.00				9,831	0.0	0	19,628	

## STREAM FLOWS

Gauging Station	07/26/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	73	2,201
NRTT: Nueces River at Tilden, Texas	0	0
FRTT: Frio River at Tilden, Texas	0	3
SMTT: San Miguel Creek at Tilden, Texas	0	0
ARWT: Atascosa River at Whitsett, Texas	4	249
Release from Choke Canyon Reservoir	66	1,703
NCAT: Nueces River at Calallen, Texas	34	10,938
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	8	501

## ESTUARY INFLOWS and PASSTHRU REQUIREMENTS

(All values are in AcFt)

Target Passthru	
Monthly Target: 4,500	3,375
Salinity Relief Credit: 1,125 Effective: 07/11/2000	
Credit / -Deficit From Previous Month (Date Deficit Satisfied: 07/17/2000)	-10,596
Wastewater Return Flow Credit (Effective: 07/17/0200)	500
Required Passthru	
Target: 3,375	501
Reservoir Inflow: 501	
Estuary Inflows (Measured at NCAT)	10,938
PassThru Surplus / -Deficit:	341

Report Generated: 07/27/2000 at 8:39:15 AM

# Choke Canyon / Lake Corpus Christi Reservoir System Daily Status Report Report Date: July 28, 2000

## RESERVOIR STATISTICS

	Choke Canyon Reservoir				Lake Cor	pus C	hristi		Combined Reservoir System		
Date	Elevation (Ft)	Volume (AcFt)	Perce Capa		Elevation (Ft)	Volu (Ac	ume :Ft)	Percent of Capacity			Percent of Capacity
FULL	220.5	695,271		100%	94.0	241	1,241	100	% 936,5	12	100%
07/28/1999	203.9	339,866	4	8.9%	90.5	178	3,153	73.8	% 518,0	19	55.3%
07/28/2000	198.9	261,220	3	7.6%	85.4	85.4 99,218		41.1	% 360,438		38.5%
			Wea	ather R	elated Inf	orma	tion				
	Cho	ke Canyor	Reser	voir	Lal	rpus (	ervoir	(	Combined		
Date	Air Temp	Evapor (Acl		Rainfa (Inche		-	mp Evaporation (AcFt)		Rainfall (Inches)	E	vaporation (AcFt)
07/27/2000	102		338	0.	.00 10	1		340	0.00		678
MTD			10,135	0.	.00			10,171	0.00		20,306

## STREAM FLOWS

Gauging Station	07/27/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	73	2,275
NRTT: Nueces River at Tilden, Texas	0	0
FRTT: Frio River at Tilden, Texas	0	3
SMTT: San Miguel Creek at Tilden, Texas	0	0
ARWT: Atascosa River at Whitsett, Texas	3	251
Release from Choke Canyon Reservoir	66	1,769
NCAT: Nueces River at Calallen, Texas	18	10,956
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	8	509

## **ESTUARY INFLOWS and PASSTHRU REQUIREMENTS** (All values are in AcFt)

Target Passthru	
Monthly Target: 4,500	3,375
Salinity Relief Credit: 1,125 Effective: 07/11/2000	
Credit / -Deficit From Previous Month (Date Deficit Satisfied: 07/17/2000)	-10,596
Wastewater Return Flow Credit (Effective: 07/17/0200)	500
Required Passthru	
Target: 3,375	509
Reservoir Inflow: 509	
Estuary Inflows (Measured at NCAT)	10,956
PassThru Surplus / -Deficit:	351

Report Generated: 07/28/2000 at 8:31:04 AM

## Choke Canyon / Lake Corpus Christi Reservoir System Daily Status Report Report Date: July 29, 2000

## RESERVOIR STATISTICS

	Choke Canyon Reservoir				La	ike Cor	pus C	hristi	Comb	Combined Reservoir System		
Date	Elevation (Ft)	Volume (AcFt)	Percent of Capacity			ration Volume Ft) (AcFt)		Percent of Capacity			Percent of Capacity	
FULL	220.5	695,271		100%		94.0	241	,241	100	% 936,51		100%
07/29/1999	203.9	339,525	48.8%			90.5	177	7,298 73		% 516,8	23	55.2%
07/29/2000	198.9	260,785	3	7.5%		85.3 98,312		40.8	% 359,0	97	38.3%	
			Wea	ather F	Rela	ted Info	orma	tion				
	Cho	ke Canyor	Reser	voir		Lake Corpus Christi Reservoir					Combined	
Date	Air Temp	Evapor (Acl		Rainfall (Inches)					poration AcFt)	Rainfall (Inches)	E	vaporation (AcFt)
07/28/2000	99		397	397 (		97			338	0.00		735
MTD			10,532	0	0.00				10,509	0.00		21,041

## STREAM FLOWS

Gauging Station	07/28/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	71	2,346
NRTT: Nueces River at Tilden, Texas	0	0
FRTT: Frio River at Tilden, Texas	0	3
SMTT: San Miguel Creek at Tilden, Texas	0	0
ARWT: Atascosa River at Whitsett, Texas	3	254
Release from Choke Canyon Reservoir	66	1,834
NCAT: Nueces River at Calallen, Texas	52	11,008
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	6	515

## **ESTUARY INFLOWS and PASSTHRU REQUIREMENTS** (All values are in AcFt)

Target Passthru  Monthly Target: 4,500 Salinity Relief Credit: 1,125 Effective: 07/11/2000	3,375
Credit / -Deficit From Previous Month (Date Deficit Satisfied: 07/17/2000)	-10,596
Return Flow Credit (Effective: 07/17/0200)	500
Passthru Target: 3,375 Reservoir Inflow: 515	515
Estuary Inflows (Measured at NCAT)	11,008
PassThru Surplus / -Deficit:	397

Report Generated: 07/29/2000 at 8:36:50 AM

# Choke Canyon / Lake Corpus Christi Reservoir System Daily Status Report Report Date: July 30, 2000

## RESERVOIR STATISTICS

	Choke Canyon Reservoir				La	pus C	hristi	Com	Combined Reservoir System				
Date	Elevation (Ft)	Volume (AcFt)	Percent of Capacity		Elevation   Volu			Percent of Capacity	-		Percent of Capacity		
FULL	220.5	695,271		100%		94.0 241,241		100	% 936,	512	100%		
07/30/1999	203.9	338,845	48.7%			90.5 176,9		5,956	73.4	% 515,	801	55.1%	
07/30/2000	198.9	260,351	37.4%		85.2		97	7,797	40.5	% 358,	148	38.2%	
			Wea	ather F	Relat	ed Info	orma	tion					
	Choke Canyon Reservoir						Lake Corpus Christi Reservoir					Combined	
Date	Air Temp (°F)	Evapor (Acl		Rainf (Inch		Air Temp (°F)			poration AcFt)	Rainfal (Inches)		Evaporation (AcFt)	
07/29/2000	96		371 (		0.00	00 99			344	0.0	0	715	
MTD			10,903	0	0.00				10,853	0.0	0	21,756	

#### STREAM FLOWS

Gauging Station	07/29/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	71	2,418
NRTT: Nueces River at Tilden, Texas	0	0
FRTT: Frio River at Tilden, Texas	0	3
SMTT: San Miguel Creek at Tilden, Texas	0	0
ARWT: Atascosa River at Whitsett, Texas	2	256
Release from Choke Canyon Reservoir	66	1,900
NCAT: Nueces River at Calallen, Texas	52	11,059
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	6	521

## ESTUARY INFLOWS and PASSTHRU REQUIREMENTS

(All values are in AcFt)

Target Passthru	
Monthly Target: 4,500	3,375
Salinity Relief Credit: 1,125 Effective: 07/11/2000	
Credit / -Deficit From Previous Month (Date Deficit Satisfied: 07/17/2000)	-10,596
Return Flow Credit (Effective: 07/17/0200)	500
Passthru	
Target: 3,375	521
Reservoir Inflow: 521	
Estuary Inflows (Measured at NCAT)	11,059
PassThru Surplus / -Deficit:	442

Report Generated: 07/30/2000 at 8:33:58 AM

## Choke Canyon / Lake Corpus Christi Reservoir System Daily Status Report Report Date: July 31, 2000

## RESERVOIR STATISTICS

	Choke Canyon Reservoir				La	pus C	hristi	Comb	Combined Reservoir System				
Date	Elevation (Ft)	Volume (AcFt)	Percent of Capacity			Clevation   Volume (Ft)   (AcFt)		-	Percent of   Vo		ne t)	Percent of Capacity	
FULL	220.5	695,271		100%		94.0	241	1,241	100	% 936,:	512	100%	
07/31/1999	203.8	338,335	48.7%			90.4 176,615		73.2	.2% 514,		55.0%		
07/31/2000	198.9	260,061	3	7.4%		85.2 97,28		7,285	40.3	% 357,	346	38.2%	
			Wea	ather F	Rela	ted Info	orma	tion					
	Cho	ke Canyor	Reser	voir		Lake Corpus Christi Reservo						Combined	
Date	Air Temp	Evapor (Acl				Air Temp   1		1	poration AcFt)	Rainfall (Inches)		vaporation (AcFt)	
07/30/2000	98		379	379 0.		100	)		283	0.00	)	662	
MTD			11,282	0	0.03				11,136	0.00		22,418	

## STREAM FLOWS

Gauging Station	07/30/2000 (AcFt)	MTD (AcFt)
NTRT: Nueces River at Three Rivers, Texas	71	2,489
NRTT: Nueces River at Tilden, Texas	0	0
FRTT: Frio River at Tilden, Texas	0	3
SMTT: San Miguel Creek at Tilden, Texas	0	0
ARWT: Atascosa River at Whitsett, Texas	2	259
Release from Choke Canyon Reservoir	66	1,965
NCAT: Nueces River at Calallen, Texas	16	11,075
Reservoir Inflow		
Computed as: (NTRT+FRTT+SMTT)-Release From Choke Canyon	6	527

## **ESTUARY INFLOWS and PASSTHRU REQUIREMENTS** (All values are in AcFt)

Target Passthru Monthly Target: 4,500 Salinity Relief Credit: 1,125 Effective: 07/11/2000	3,375
Credit / -Deficit From Previous Month (Date Deficit Satisfied: 07/17/2000)	-10,596
Return Flow Credit (Effective: 07/17/0200)	500
Passthru Target: 3,375 Reservoir Inflow: 527	527
Estuary Inflows (Measured at NCAT)	11,075
PassThru Surplus / -Deficit:	453

Report Generated: 07/31/2000 at 8:31:41 AM